# Voltage Collapse in Complex Power Grids

John W. Simpson-Porco<sup>\*1</sup>, Florian Dörfler<sup>2</sup>, and Francesco Bullo<sup>3</sup>

#### Abstract

A large-scale power grid's ability to transfer energy from producers to consumers is constrained by both the network structure and the nonlinear physics of power flow. Violations of these constraints have been observed to result in voltage collapse blackouts, where nodal voltages slowly decline before precipitously falling. However, methods to test for voltage collapse are dominantly simulation-based, offering little theoretical insight into how grid structure influences stability margins. For a simplified power flow model, here we derive a closed-form condition under which a power network is safe from voltage collapse. The condition combines the complex structure of the network with the reactive power demands of loads to produce a node-by-node measure of grid stress, a prediction of the largest nodal voltage deviation, and an estimate of the distance to collapse. We extensively test our predictions on large-scale systems, highlighting how our condition can be leveraged to increase grid stability margins.

# Introduction

Modern power grids are some of the largest and most complex engineered systems. Currently however, growing consumer demand and the transition to distributed and deregulated small-scale generation are leading to increased system stress, and grid operators have strong economic incentives to operate networks close to their physical limits [1, 2, 3]. When these physical limits are approached or breached, power systems can experience a form of network-wide failure termed voltage collapse

<sup>&</sup>lt;sup>1</sup>Department of Electrical and Computer Engineering, Engineering Building 5, University of Waterloo, Waterloo, ON N2L 3G1 Canada. Correspondence: jwsimpson@uwaterloo.ca.

<sup>&</sup>lt;sup>2</sup>Automatic Control Laboratory, Swiss Federal Institute of Technology (ETH), Physikstrasse 3, CH-8092 Zürich.

<sup>&</sup>lt;sup>3</sup>Center for Control, Dynamical Systems and Computation and Department of Mechanical Engineering, Engineering Building II, University of California at Santa Barbara, Santa Barbara, CA 93106-9560 USA.

[4, 5, 6, 7, 8]. Voltage collapse and related instabilities have been identified as contributing factors in several recent large-scale blackouts, including Scandinavia (2003), the northeastern United States (2003), Athens (2004) and Brazil (2009) [7, 8, 9]. An obstacle in predicting voltage collapse is the extensive use of capacitor banks to hold up voltage levels at substations and along transmission lines. This voltage support keeps the system within operational constraints, but conceals the low stability margin of the network, leading to increased blackout risk [7, 10]. Voltage fluctuations are presently being further aggravated by the increasing integration of utility-scale wind and photovoltaic sources. A key problem is therefore to develop physically insightful, easily computable stability conditions under which a network is safe from voltage collapse.

Applications of network theory and statistical mechanics to power transmission networks have to this point focused heavily on synchronization [11, 12, 13, 14, 15, 16, 17, 18, 19], a phenomenon associated with the self-stabilizing collective behavior of synchronous generators [20]. Synchronization is primarily controlled by the flow of active power; the real power used by loads to do work [8]. Interest in synchronization has led to a robust theoretical understanding of active power [21, 22, 1, 16, 23], and a plethora of closed-form conditions under which power networks synchronize. In contrast, voltage collapse — a collective nonlinear *instability* [4, 5, 7] — has received little attention from a network perspective.

While voltage collapse is a multifaceted phenomena involving generator and transformer limits, the most important fundamental effect is a saddle-node bifurcation of the network equations, resulting in the loss of system equilibrium. Voltage phenomena are driven primarily by *reactive power*, a much less intuitive concept than active power. Reactive power represents the ebb and flow of energy in the electromagnetic fields of system components. This energy is stored and released during each AC cycle, allowing system components to function normally and to facilitate the transfer of useful active power with minimal transmission losses [7]. Understanding and controlling reactive power is therefore essential for the efficient and safe operation of the grid.

Theoretical understanding of reactive power flow and voltage collapse in complex networks is poor however, and numerical simulation is currently the only satisfactory approach to guard against voltage collapse; see [24, 25, 26, 4, 5, 27, 28, 29, 7] for numerical tests based on sensitivity matrices, and [30, 31, 32, 10, 1, 23] for approaches based on continuation methods, optimization, and energy methods. The network is usually analyzed not only under normal conditions, but under a large set of contingencies generated from single-component failures. A broad survey of computational approaches can be found in [33]. While effective computational tools in practice, these numerical approaches often offer little theoretical insight into how the underlying parameters and network structure influence voltage stability. An exception is the branch flow monitoring approach in [34, 35], where voltage collapse and network structure are linked by showing that collapse is preceded by the saturation of transfer paths between sources and sinks of power (Supplementary Note 2).

In contrast with computational methods focused on predicting voltage collapse with great accuracy, here we develop a simple and new analytical framework for analyzing voltage collapse, and focus in particular on understanding how the structure of the network influences stability margins. While previous analytic works [36, 37] have relied on spectral graph measures such as algebraic connectivity [14, 13, 16], the closed-form voltage stability condition we propose below accounts for the grid structure by simultaneously incorporating all eigenvalues of an appropriate system matrix, and combines this information with the sizes and locations of shunt capacitors and loads. To our knowledge, this stability condition is the first to achieve this combination. Our analysis, which is based on a simplified power flow model, yields predictions for the voltage profiles of power grids and provides an explicit stability margin against voltage collapse. The predictions are found to be quite accurate in standard test cases. Our approach is not only mathematically accurate, but also appealing and intuitive to scholars versed in network science and dynamic processes over networks. Since we focus on the influence of grid structure on voltage collapse, we analyze the simplest possible network model that captures the essential bifurcation phenomena; we discuss important extensions involving second order effects due to active power coupling as well as component failures in the Discussion section. While our simplified model does not account for active power coupling, we show through extensive numerical experiments that our predictions remain robust when including these effects, and we specifically highlight when they break down.

## Results

#### **Power Network Modeling**

We consider a high-voltage power network with  $n \ge 1$  load nodes and  $m \ge 1$  generator nodes, and in this article we focus on the decoupled reactive power flow equations

$$Q_i = -\sum_{j=1}^{n+m} V_i B_{ij} V_j , \qquad i \in \{1, \dots, n\},$$
(1)

where  $Q_i$  (resp.  $V_i$ ) is the reactive power demanded (resp. voltage magnitude) at load  $i \in \{1, \ldots, n\}$ . Voltage magnitudes  $V_j$  at generators nodes  $j \in \{n + 1, ..., n + m\}$  are regulated by internal controllers to constant values, and the sum in (1) therefore contains both quadratic and linear terms in the unknown load voltages  $\mathbf{V}_{\mathrm{L}} = (V_1, \ldots, V_n)$ . The symmetric coefficients  $B_{ij} = B_{ji}$ quantify the effective strength of connection between nodes i and j. These coupling coefficients have the form  $B_{ij} = b_{ij} \cos(\theta_i - \theta_j)$ , where  $b_{ij} \ge 0$  quantifies the strength of the transmission line joining nodes i and j, and  $\theta_i - \theta_j$  is the difference between the angles of the voltage phasors at the two nodes. These phase angles may be estimated in advance using a decoupled active power flow model [38], or come from the output of a numerical power flow solver. The diagonal elements are defined by  $B_{ii} = -\sum_{j \neq i} b_{ij} + b_{ii}$ , where  $b_{ii}$  accounts for inductive or capacitive shunts (connections The sparsity pattern of the matrix  $B_{ij}$  therefore encodes both the structure of to ground). the physical network and the degree of coupling between nodes after accounting for active power transfers. Equation (1) arises from considering the balance of reactive power at each node in the network while neglecting second-order effects accounting for coupling with active power flows and phase angle dynamics; more modeling information may be found in (Supplementary Note 3).

A novel mechanical analogy for the power flow (1) is shown in Fig. 1(b). The equilibrium configuration of the spring network corresponds to the desirable high-voltage solution of (1), and can be interpreted as a local minimum (Fig. 1(c)) of the energy function [31]

$$E(V_1, \dots, V_n) = \frac{1}{2} \sum_{i=1}^n \sum_{j=i+1}^{n+m} B_{ij} (V_i - V_j)^2 - \sum_{i=1}^n \left( \frac{1}{2} \kappa_i V_i^2 + Q_i \ln(V_i) \right), \quad (2)$$



Figure 1: Mechanical and energy interpretations of power flow. (a) An example power network with two generators (green) supplying power to three loads (red). Power demands  $(Q_1, Q_2, Q_3)$  are placed on the load nodes; (b) a mechanical analogy: a linear spring network placed in a potential field. The generator voltages (green) are "pinned" at constant values, while the load voltages (red) are masses "hanging" off the generators, their equilibrium values being determined by their weights (the power demands  $\mathbf{Q}_{\mathrm{L}} = (Q_1, Q_2, Q_3)$ ), the heights of the fixed generator voltages  $(V_4, V_5)$ , and by the stiffness of the spring network (the susceptance matrix **B**). Voltage collapse can occur when one of the masses crosses an appropriate collapse boundary curve; (c) Contour plot of energy function when  $Q_3 = 0$  and node 3 is eliminated via Kron reduction [13]. Since  $E(\mathbf{V}_{\mathrm{L}})$  contains logarithms, it tends to  $-\infty$  as either axis is approached. In a normalized system of units, the stable high-voltage equilibrium rests in a local minimum at (0.94, 0.94), while an unstable low-voltage equilibrium sits at the saddle (0.68, 0.30). Voltage collapse occurs when these equilibria coalesce and the system trajectory diverges.

where  $\kappa_i \triangleq \sum_{j=1}^{n+m} B_{ij}$  (Supplementary Note 4). Note that the power demands  $Q_i$  generate a logarithmic potential, leading to multiple equilibria (Fig. 1(c)). Standard practice is that for stable and economical network operation with minimal transmission losses, nodal voltages should remain near their open-circuit values as obtained for an unloaded (and thus unstressed) network [8]. Intuitively then, a stable steady-state is characterized by

$$|V_i - V_i^*| / V_i^* \le \delta, \qquad i \in \{1, \dots, n\},$$
(3)

where  $V_i^*$  is the open-circuit voltage at the *i*th node and  $\delta > 0$  is a dimensionless variable quantifying an allowable percentage limit on deviations. Intuition from Fig. 1 suggests that a stiff, lightly loaded grid will have a high and uniform voltage profile with small deviation  $\delta$ , while a weak, heavily loaded grid will result in voltage collapse. The following analytic results will make this intuition precise and mathematically accurate.

#### Analytic Results

We suggest that for assessing voltage stability and collapse, one should consider not the underlying electrical network encoded in the susceptance matrix **B**, but a reduced and re-weighted auxiliary network. This auxiliary network shares the same topology as the physical network, but with new edge weights which encode both generator voltage levels and the topology and strength of connections between loads and generators. After potentially reordering the network nodes so that loads and generators are labeled, respectively  $\{1, \ldots, n\}$  and  $\{n + 1, \ldots, n + m\}$ , we may partition the  $(n + m) \times (n + m)$  coupling matrix **B** with elements  $B_{ij}$  into four block matrices as

$$\mathbf{B} = \begin{pmatrix} \mathbf{B}_{\mathrm{LL}} & \mathbf{B}_{\mathrm{LG}} \\ \mathbf{B}_{\mathrm{GL}} & \mathbf{B}_{\mathrm{GG}} \end{pmatrix}.$$
 (4)

The  $n \times n$  sub-matrix  $\mathbf{B}_{\mathrm{LL}}$  now describes the interconnections among loads, while the  $n \times m$  matrix  $\mathbf{B}_{\mathrm{LG}}$  specifies the interconnections between loads and generators. This partitioning suggests a natural mapping from generators to loads through the matrix  $\mathbf{B}_{\mathrm{LL}}^{-1}\mathbf{B}_{\mathrm{LG}}$ , which we can use to define the open-circuit load voltages  $\mathbf{V}_{\mathrm{L}}^* = (V_1^*, \dots, V_n^*)$  by

$$\mathbf{V}_{\mathrm{L}}^{*} = -\mathbf{B}_{\mathrm{LL}}^{-1}\mathbf{B}_{\mathrm{LG}}\mathbf{V}_{\mathrm{G}}\,,\tag{5}$$

where  $\mathbf{V}_{G} = (V_{n+1}, \dots, V_{n+m})$  is the vector of fixed generator voltages. To quantify the stiffness of the spring network in Fig. 1(b), we combine the nominal voltages (5) with the sub-matrix  $\mathbf{B}_{LL}$  in equation (4) to obtain the symmetric stiffness matrix

$$\mathbf{Q}_{\text{crit}} \triangleq \frac{1}{4} \operatorname{diag}(\mathbf{V}_{\mathrm{L}}^{*}) \cdot \mathbf{B}_{\mathrm{LL}} \cdot \operatorname{diag}(\mathbf{V}_{\mathrm{L}}^{*}), \qquad (6)$$

where diag( $\mathbf{V}_{\mathrm{L}}^{*}$ ) is the matrix with  $(V_{1}^{*}, \ldots, V_{n}^{*})$  on the main diagonal. In other words,  $\mathbf{Q}_{\mathrm{crit}}$  has units of power and its *ij*th entry is given by  $V_{i}^{*}V_{j}^{*}B_{ij}/4$ . Selected topological features, edge weights, generator voltages, and the relative locations of generators and loads are all concisely encoded in the stiffness matrix  $\mathbf{Q}_{\mathrm{crit}}$ . Just as the stiffness matrix of a standard spring network relates displacements to spring forces, the matrix  $\mathbf{Q}_{\text{crit}}$  can be thought of as relating the dimensionless voltage deviations  $(V_i - V_i^*)/V_i^*$  to the reactive power demands  $\mathbf{Q}_{\text{L}} = (Q_1, \ldots, Q_n)$ . Indeed, this normalization to dimensionless variables is key to our theoretical analysis. To arrive at small normalized deviations of the form (3), it then seems reasonable that the dimensionless matrix-vector product  $\mathbf{Q}_{\text{crit}}^{-1}\mathbf{Q}_{\text{L}}$  should be small in some sense. Our main result below shows that this intuition based on linear spring networks can be made precise, leading to guarantees on voltage deviations for the nonlinear network (1). A derivation and a formal proof can be found in the Methods section and in (Supplementary Note 5), respectively.

Theorem 1: The power flow equations (1) have a unique, stable, high-voltage solution  $(V_1, \ldots, V_n)$  if

$$\Delta = \left\| \mathbf{Q}_{\text{crit}}^{-1} \mathbf{Q}_{\text{L}} \right\|_{\infty} < 1,$$
(7)

where  $\|\mathbf{Q}_{\text{crit}}^{-1}\mathbf{Q}_{\text{L}}\|_{\infty}$  is the largest magnitude of the entries of the vector  $\mathbf{Q}_{\text{crit}}^{-1}\mathbf{Q}_{\text{L}}$ . Moreover, each component  $V_i$  of the unique high-voltage solution satisfies the bound  $|V_i - V_i^*|/V_i^* \leq \delta_-$ , where  $\delta_- = (1 - \sqrt{1 - \Delta})/2$ .

The matrix-vector product  $\mathbf{Q}_{\text{crit}}^{-1}\mathbf{Q}_{\text{L}}$  captures the interaction between the auxiliary network structure and the locations of loads, with the infinity norm  $\|\cdot\|_{\infty}$  identifying the maximally stressed node. The scalar  $\delta_{-}$  then bounds the largest voltage deviation in the network. No reactive loading corresponds to zero stress  $\Delta = 0$  and  $\delta_{-} = 0$ ; voltages align with their open-circuit values. Conversely, when  $\Delta = 1$ , the network's guaranteed stability margin has been depleted. Said differently,  $\Delta < 1$  guarantees the existence of a stable equilibrium, while  $\Delta \geq 1$  is a necessary condition for voltage collapse, where at least one node of the network has become overly stressed. The stability condition (7) can be therefore be interpreted as a dual to previous literature showing that voltage collapse is always preceded by at least one edge of the network becoming overly stressed [34, 35]. Moreover, the bound  $\Delta < 1$  is the *tightest* possible general bound, as cases can be constructed where voltage collapse occurs at  $\Delta = 1$  (Supplementary Note 5, Remark 4). Note that (6) captures the desired intuition of the spring network analogy in Fig. 1(b); the network stiffness matrix  $\mathbf{Q}_{\text{crit}}$ should be large when compared to the reactive loading  $\mathbf{Q}_{\text{L}}$ ; see (Supplementary Note 5) for complex network, power system, and circuit-theoretic interpretations of the stability condition. In terms of Fig. 1(c),  $\sqrt{1-\Delta}$  lower bounds the distance in voltage-space between the stable and unstable equilibria in the power system energy landscape. In summary, the stability condition (7) concisely and elegantly captures the physical intuition developed in Fig. 1 and in the previous section, and guarantees the existence of a unique equilibrium for the nonlinear network equations (1).

For fixed reactive demands  $\mathbf{Q}_{\mathrm{L}}$ , the stability test (7) states that the largest stability margins are obtained by making  $\mathbf{Q}_{\text{crit}}^{-1}$  small. Since the parameters of the grid are embedded in the stiffness matrix  $\mathbf{Q}_{\text{crit}}$  defined in (6), the stability test (7) provides insight into how the parameters of the network influence its stability margins. Rigorous statements may be found in (Supplementary Note 6), while here we present the key insights. For example, by examining the definitions (5) and (6) one observes that raising generator voltage levels  $V_{\rm G}$  will weaken (in magnitude) the elements of  $\mathbf{Q}_{\text{crit}}^{-1}$  and therefore increase stability margins. In terms of Fig. 1(b), this corresponds to "raising the ceiling", which increases the distance to the stability boundary. Since the coupling weights  $B_{ij}$  enter the stiffness matrix (6) both directly and through the open-circuit voltages  $\mathbf{V}_{\mathrm{L}}^*$ , their effects on stability margins are subtle, and counter-examples can be constructed where increasing the coupling between generators and loads decreases stability margins (Supplementary Note 6). Nonetheless, one may show rigorously that under normal network conditions, strengthening the edge weights  $B_{ij}$  between loads and generators and increasing the shunt capacitances  $b_{ii}$  at loads are both beneficial to stability margins. The first corresponds to stiffening the springs (4, 2) and (5,3) of Fig. 1(b), while the second can be thought of as extra upward force directly applied to nodes  $\{1, 2, 3\}$ . In summary, the stability condition (7) can be leveraged to provide new qualitative insights into how the network structure and parameters influence stability margins.

Finally, in contrast to standard voltage collapse studies, note that we have made no assumptions about the direction of the reactive power demands  $\mathbf{Q}_{\mathrm{L}}$ , which appear linearly in (7). Therefore, the condition (7) simultaneously accounts for all directions in the space of reactive power demands. This generality may result in the test (7) being conservative for a particular direction in the space of power demands. On the other hand, this generality allows one to assess network stability for an entire set of possible power demands via a single evaluation of the condition (7). The inverse of the stiffness matrix is the sensitivity matrix relating percentage changes in voltage to changes in reactive demands  $\mathbf{Q}_{\mathrm{L}}$ , as can be seen from the linearized relationship  $(V_i - V_i^*)/V_i^* =$  $-(\mathbf{Q}_{\mathrm{crit}}^{-1}\mathbf{Q}_{\mathrm{L}})_i/4$ . A comparison of the stiffness matrix  $\mathbf{Q}_{\mathrm{crit}}$  and its inverse is shown in Fig. 2. The stiffness matrix  $\mathbf{Q}_{\mathrm{crit}}$  is itself very sparse, mirroring the physical topology of the grid. This sparsity allows the inequality (7) to be rapidly checked by solving a sparse linear system  $\mathbf{Q}_{\mathrm{crit}}\mathbf{x} = \mathbf{Q}_{\mathrm{L}}$ ; the vector  $\mathbf{x}$  serves as a linear approximation of (and an upper bound on) the exact voltage deviations  $(V_i - V_i^*)/V_i^*$ . In contrast, the inverse  $\mathbf{Q}_{\mathrm{crit}}^{-1}$  is a dense matrix with significant off-diagonal elements, indicating the importance of not only local but also multi-hop interactions. While we omit the details here, the stability condition (7) can be extended to additionally guarantee the satisfaction of hard, predefined limits on both voltage magnitudes and the reactive power injections of generators (Supplementary Note 5, Remark 2 and Supplementary Note 6, respectively).



Figure 2: Sparsity patterns of network matrices for 57 node test case. (a) the stiffness matrix  $\mathbf{Q}_{\text{crit}}$  representing the auxiliary network. (b) The inverse stiffness matrix  $\mathbf{Q}_{\text{crit}}^{-1}$ . The 57 node network contains 50 loads and 7 generators. Nodes are sorted and grouped by connected components of the subgraph induced by  $\mathbf{Q}_{\text{crit}}$ , with connected components ordered from largest to smallest; nodes  $\{1, \ldots, 48\}$  are part of one large connected component, while nodes  $\{49, 50\}$  each constitute their own component. Color scale represents normalized values of the matrix elements, with dark blue being zero and red being one. Diagonal elements of  $\mathbf{Q}_{\text{crit}}$  are displayed in absolute value for clarity.

#### Numerical Assessment of Voltage Stability Condition

In this section we provide three numerical studies to assess the accuracy of the stability condition (7) in large-scale power networks, and to determine its predictive limitations. Our first study focuses on the accuracy of the theoretical bound  $|V_i - V_i^*|/V_i^* \leq \delta_-$  in typical networks operating in the normal regime far away from voltage collapse. We consider eleven widely-established test cases [39], ranging from a small 9 node network to a representation of the Polish grid with nearly 2400 nodes. To generate a diverse set of sample networks, we construct 1000 realizations of each network, with up to 30% deviation from forecast conditions in generation and up to 50% deviation in active and reactive power demands, drawn from a normal distribution centered around base conditions; see (Supplementary Methods) for details. For each realization, we solve the more realistic lossless coupled active/reactive AC power flow equations numerically, and we compare the largest nodal voltage deviation  $\delta_{\text{exact}} = \max_i |V_i - V_i^*|/V_i^*$  from the numerically determined voltage profile to the analytic bound  $\delta_- = \frac{1}{2}(1 - \sqrt{1 - \Delta})$  from our main result (7) based on the simplified model (1) with the numerically determined phase angles  $\theta_i - \theta_j$  substituted.

Our findings are reported in Table 1. The theoretical prediction of the stability test (7) is that  $\delta_{\text{exact}} \leq \delta_{-}$ ; the first column indicates that this inequality held for all realizations for which the numerical solver converged. All realizations for which the numerical solver failed to converge were discarded; this occurred in fewer than 1% of all cases. The second and third columns list the average values of these two quantities over all realizations. As can be seen, these voltage deviations range from roughly 1% to 6% from open-circuit conditions. The final column shows the average of the prediction error  $(\delta_{-} - \delta_{\text{exact}})/\delta_{\text{exact}}$  over all realizations. For all networks from 9 to 2383 nodes (except the 57 and 300 node networks) the prediction error is less than 1%, indicating that prediction accuracy is not directly dependent on system size. Perhaps surprisingly considering the simplicity of the condition (7), the least accurate prediction overestimates voltage deviations by only 3.8%. We conclude that for normally stressed large-scale networks, the bounds predicted by the stability condition (7) hold and are accurate even when tested on more complicated coupled power flow models.

Our second study analyzes the predictions of (7) in a highly stressed network, again for the morerealistic lossless coupled active/reactive power flow model. As our focus is on studying bifurcation phenomena for the network equations, we discard generator limitations in this study and assume internal generator controls hold the network-side generator voltages constant; see (Supplementary Note 7) for theoretical extensions which include generator limits. As we noted previously,  $\Delta \geq 1$ is a necessary condition for voltage collapse, and we now test the gap between this necessary condition and true point of collapse. We consider the 39 node reduced representation of the New England power grid, illustrated in Fig. 5(a). Beginning from normal base case loading conditions, the active and reactive power demands and generation are increased continuously along a chosen ray in parameter-space, with the size of the increase parameterized by a scalar  $\lambda$ , until voltage collapse occurred at a value  $\lambda = \lambda_{\text{collapse}}$ . For each  $\lambda \in [0, \lambda_{\text{collapse}}]$ , we determine numerically the system equilibrium and recalculate  $\Delta$  from (7) using the numerically determined phase angles  $\theta_i - \theta_j$ .

The above testing procedure obviously depends on the choice of direction for increase in the space of power demands and generation. We select two directions and study them separately, to illustrate the strengths and limitations of our analytic approach based on a simplified power flow model. As a first choice, we select a direction where the mean power factor<sup>4</sup> in the network is decreased 20% to a value of 0.7. This corresponds to a case where loads consume roughly equal amounts of active and reactive power, which in practice is unusually highly reactive power consumption. We therefore expect that instabilities associated with reactive power flow should dominate any unmodeled active power effects, and the simplified model (1) should serve as a good proxy for the coupled active/reactive power flow equations. As a function of  $\lambda$ , Fig. 3 displays the trace of the voltage magnitude at node 4 (solid black), the loading margin  $\Delta$  (dashed blue), and the bound  $V_4^*(1 - \delta_-)$  (dotted red) determined by (7). Node 4 was determined through (7) to be the most stressed node in the network, and hence the node for which our theoretical bound would be best tested. First, observe that the numerically determined voltage trace is bounded below by the trace

<sup>&</sup>lt;sup>4</sup>The power factor of the *i*th load is defined as  $P_i/\sqrt{(P_i^2 + Q_i^2)}$ , where  $P_i$  is the active power drawn by the load. If  $P_i = Q_i$ , then the power factor is 0.707.

of the theoretical bound, as expected. The loading margin  $\Delta$  increases roughly linearly with  $\lambda$ , with  $\Delta = 1$  occurring at  $\lambda/\lambda_{\text{collapse}} = 0.98$ . Our previous conclusions regarding the necessity of  $\Delta > 1$  for voltage collapse therefore hold in this highly stressed case for the more complicated coupled active/reactive power flow model, and the gap between the necessary condition  $\Delta > 1$  and the true point of collapse is a surprisingly small 2%.



Figure 3: Stress testing of voltage stability condition for low power factor loading. The horizontal voltage axis is scaled by  $V_{\text{base}} = 345 \text{ kV}$ . The solid black trace is the numerically computed voltage magnitude at node four, while the dotted red trace is given explicitly by  $V_4^*(1-\delta_-)$ , where  $\delta_-$  is determined as below (7). The stability margin  $\Delta$  is shown in dashed blue. When  $\Delta > 1$ ,  $\delta_-$  becomes undefined and the corresponding bound is no longer plotted.

As a second loading direction for testing, we maintain the direction of the base case, for which the average power factor of loads is approximately 0.88. In this regime reactive power transfers will be less prominent, and we expect the unmodeled coupling between active and reactive power flows to induce voltage collapse at a loading level lower than expected from the simplified model (1). Again as a function of  $\lambda$ , Fig. 4 displays the desired traces. While the trace of  $V_4^*(1-\delta_-)$  continues to lower bound the trace of the node voltage  $V_4$ , we find in this case that  $\Delta = 0.75$  when voltage collapse occurs for the coupled equations at  $\lambda/\lambda_{\text{collapse}} = 1$ . As expected, in this regime the unmodeled coupled power flow effects become crucial and the simplified decoupled model (1), on which our

analysis is based, becomes invalid. Said differently, when reactive power demands in the network are low, our analytic prediction of the point of voltage collapse based on the simplified model (1) is overly optimistic. We comment further on extensions of our analysis to the coupled case in the Discussion and in (Supplementary Note 5).



Figure 4: Stress testing of voltage stability condition for high power factor loading. The horizontal voltage axis is scaled by  $V_{\text{base}} = 345 \text{ kV}$ . The solid black trace is the numerically computed voltage magnitude at node four, while the dotted red trace is given explicitly by  $V_4^*(1-\delta_-)$ , where  $\delta_-$  is determined as below (7). The stability margin  $\Delta$  is shown in dashed blue.

Our final study illustrates the use of our stability condition (7) for determining corrective actions, with the goal of increasing grid stability margins. The New England grid in Fig. 5(a) is experiencing peak loading conditions, and shunt capacitors have been switched in at all substations (red nodes) to support voltage magnitudes, keeping the voltage profile (solid black in Fig. 5(b)) within operational bounds (dotted gray). Node 8 is under particularly heavy loading with a poor power factor of 0.82, and additional shunt capacitors at nodes 7 through 9 have been used to support the voltages in this area. While all voltages are maintained within the operational bounds, we calculate using the condition (7) that  $\Delta = 0.64$ , indicating the network is actually under significant stress. This stress is also apparent by numerically solving the lossy coupled power flow equations plotting the ratio  $V_i/V_i^*$  of the nodal voltage to the open-circuit voltage (solid red in Fig. 5(b)), as these ratios take into account the effects of shunt compensation; node 8 is experiencing the greatest stress. Consider the possibility of control equipment being present at the *i*th node of the network, capable of supplying an additional amount of reactive power  $q_i$  to the grid. Our goal is to select  $\mathbf{q} = (q_1, \ldots, q_n)$  to optimally increase grid stability margins. Such control could be realized actively through power electronic devices, or passively by curtailing local power consumption; in either case it is also desirable to minimize the total control action.

With this additional control capability, the stability metric (7) is modified to  $\|\mathbf{Q}_{crit}^{-1}(\mathbf{Q}_{L} + \mathbf{q})\| < 1$ . One immediately observes that the elements of  $\mathbf{Q}_{crit}^{-1}$  are providing information on where control action will be the most effective. For example, suppose that control equipment is present only at nodes seven and nine, but not at node eight (Fig. 5(a)). One finds for this example that  $(\mathbf{Q}_{crit}^{-1})_{87}/(\mathbf{Q}_{crit}^{-1})_{89} = 1.98$ , indicating that control action at node seven will be nearly twice as effective in reducing stress as node eight as the same control action would be if applied at node nine. From a purely topological viewpoint, this discrepancy in control sensitivity is surprising, as both nodes are neighbors of node eight. The stiffness matrix  $\mathbf{Q}_{crit}$  incorporates not only the topology, but also the strength of connections between nodes, the locations of shunt capacitors and the relative proximity of generation (green nodes). Increasing  $q_7$  and  $q_9$  in this ratio provides the desired control action, allowing capacitor banks to be switched out, and we find that  $\Delta = 0.52$  after control. A simple heuristic control has therefore reduced network stress by  $(0.64 - 0.52)/(0.52) \simeq 23\%$ , while the voltage profile of the grid (dotted black) is essentially unchanged.

In summary, the stability condition (7) can be simply and intuitively used to select control policies which increase grid stability margins with minimal control effort; additional details on eigenvectorbased control directions [40] and on the simulation setup are available in (Supplementary Note 5, Remark 3) and (Supplementary Methods), respectively.



Figure 5: Corrective action results for the reduced New England 39 node network. (a) Depiction of the reduced New England grid. Load nodes  $\{1, \ldots, 30\}$  are red circles, while generators  $\{31, \ldots, 39\}$  are green squares. Shunt capacitors are present at all load nodes, but shown explicitly at nodes 7, 8, and 9. (b) Results of corrective action study. Voltage profile  $V_i$  (black) and scaled voltages  $V_i/V_i^*$  (red), before (solid) and after (dashed) corrective action. All voltages were scaled by the grid's base voltage  $V_{\text{base}} = 345$  kV. Horizontal dashed lines are operational limits for  $V_i$  of  $\pm 5\%$  from base voltage. For clarity only nodes  $\{1, \ldots, 20\}$  are plotted.

## Discussion

The stability condition (7) provides a long sought-after connection between network structure, reactive loading, and the resulting voltage profile of the grid. As such, the condition (7) can be used to identify weak network areas and trace geographical origins of voltage instability by examining the entries of the vector  $\mathbf{Q}_{\text{crit}}^{-1}\mathbf{Q}_{\text{L}}$ . This allows for the effective placement of voltage control equipment, and the automatic dispatch of generation to mitigate voltage fluctuations, creating a self-healing network. The condition (7) can serve as a bridge between intuition-based heuristics for voltage control and more computational optimization approaches, and the use of (7) for systematic control design is currently under investigation.

The results reported here are a first step towards an analytic approach to assessing and strengthening the voltage stability of power grids. A limitation of the current work is that active power demands are included only implicitly in the condition (7), through the stiffness matrix  $\mathbf{Q}_{\text{crit}}$  which contains the effective coupling weights  $B_{ij} = b_{ij} \cos(\theta_i - \theta_j)$ . While our formal theoretical results hold only for the approximate model, the results of Table 1 show that this approximation is extremely accurate under normal operating conditions, and the results of Figure 5 indicate that our framework provides effective control guidelines even when this assumption is violated. As can be seen from Figure 4 however, this decoupling approximation tends to degrade near points of voltage collapse, where second-order effects due to active power flows become crucial, and the predictions of the simplified decoupled model and the coupled active/reactive power flow model diverge (Supplementary Note 5, Remark 5). The key direction for future work is therefore the development of a more advanced analytic test which explicitly includes active power demands and does not require that the stiffness matrix be updated as phase angle differences  $\theta_i - \theta_j$  change. This should allow for the rigorous extension of our theoretical results to coupled active/reactive power flow. Another limitation of model (1) is the assumption that resistances between nodes in the network are negligible. While this assumption is quite reasonable in large high-voltage transmission networks, resistances nonetheless generate additional voltage drops, and losses may become sizable due to large current flows as the network becomes stressed. Extending the stability test (7) to lossy power flow models is therefore another key step toward an analytic understanding of power flow. These two extensions are under investigation, and if completed will translate the new theoretical framework presented here into a robust set of analysis and design tools for practical power grids. We expect that a generalized stiffness matrix similar to (6) will play a key role in these more general problem setups. An area where these results may have a major impact is in contingency screening, where system operators computationally assess failure scenarios to determine if the grid remains stable. Due to the low computational overhead of evaluating analytic conditions such as our stability condition (7), further developments of the theory may allow for the fast assessment of many more contingencies than is currently feasible, or a single condition could be derived which guarantees the stability of the system under all contingencies within a certain class. Finally, we note that similar matrix techniques for incorporating network structure should prove relevant in other complex networked systems displaying polynomial nonlinearities, such as ecological population models, chemical reaction networks, and viral epidemic spreading.

## Methods

Main Result Derivation: The key step in deriving (7) is recognizing the physical significance of the open-circuit voltages  $\mathbf{V}_{\mathrm{L}}^*$  in (5). Physically,  $V_i^*$  is the voltage one would measure at the *i*th node of the network when  $Q_1 = Q_2 = \cdots = Q_n = 0$ . The condition (7) was derived by reformulating the power flow (1) as a fixed point equation of the form  $\mathbf{x} = \mathbf{f}(\mathbf{x})$ , where  $x_i = (V_i - V_i^*)/V_i^*$ is a shifted and normalized voltage variable. With this notation, the power flow (1) takes the dimensionless form  $\mathbf{x} = \mathbf{f}(\mathbf{x}) \triangleq -\frac{1}{4}\mathbf{Q}_{\mathrm{crit}}^{-1}\mathrm{diag}(\mathbf{Q}_{\mathrm{L}}) \cdot \mathbf{r}(\mathbf{x})$ , where  $\mathbf{r}(\mathbf{x}) = (\frac{1}{1+x_1}, \ldots, \frac{1}{1+x_n})$ . Imposing invariance of the set  $\{x : |x_i| \leq \delta, i = 1, \ldots, n\}$  under the fixed point map  $\mathbf{f}(\cdot)$  leads to condition (7). Existence and uniqueness of the equilibrium was shown by applying the contraction mapping theorem. Finally, stability was confirmed by showing that the Hessian matrix of the energy function is positive definite at the equilibrium; see (Supplementary Note 3) and (Supplementary Note 5) for additional details.

Properties of Stiffness Matrix: In all publicly available test cases, the sub-matrix  $\mathbf{B}_{LL}$  is a

nonsingular Metzler matrix. It follows that its inverse has nonpositive elements [41], that the matrix  $-\mathbf{B}_{LL}^{-1}\mathbf{B}_{LG}$  is nonnegative, and hence that the open-circuit voltages  $\mathbf{V}_{L}^{*} = -\mathbf{B}_{LL}^{-1}\mathbf{B}_{LG}\mathbf{V}_{G}$  as defined in (5) are strictly positive. The stiffness matrix  $\mathbf{Q}_{crit}$  used in the condition (7) inherits this Metzler property, and also posses an inverse with nonpositive elements. In particular, it holds that  $(\mathbf{Q}_{crit}^{-1})_{ij} < 0$  with strictly inequality if and only if there exists a path in the network between load node *i* and load node *j* which does not intersect any generator node. Thus, reactive loading at node *j* influences the voltage at node *i* and vice-versa, even if nodes *i* and *j* are not one-hop neighbors. When there are multiple groups of loads electrically isolated from one another by generators, the stability test (7) therefore decouples into an identical test for each group.

**Numerical Studies:** Extensive details on the construction of our three numerical experiments may be found in the (Supplementary Methods). All studies were implemented using the standard power flow solution techniques from the MATPOWER package [39].

# References

- Hiskens, I. A. & Davy, R. J. Exploring the power flow solution space boundary. *IEEE Transactions on Power Systems* 16, 389–395 (2001).
- [2] Hiskens, I. A. Analysis tools for power systems contending with nonlinearities. Proceedings of the IEEE 83, 1573–1587 (2002).
- [3] Brummitt, C. D., Hines, P. D. H., Dobson, I., Moore, C. & D'Souza, R. M. Transdisciplinary electric power grid science. *Proceedings of the National Academy of Sciences* **110**, 12159 (2013).
- [4] Dobson, I. & Chiang, H. D. Towards a theory of voltage collapse in electric power systems. Systems & Control Letters 13, 253-262 (1989).
- [5] Dobson, I. Observations on the geometry of saddle node bifurcation and voltage collapse in electrical power systems. *IEEE Transactions on Circuits and Systems I: Fundamental Theory* and Applications **39**, 240–243 (1992).

- [6] Taylor, C. W. Power System Voltage Stability (McGraw-Hill, 1994).
- [7] Van Cutsem, T. & Vournas, C. Voltage Stability of Electric Power Systems (Springer, 1998).
- [8] Machowski, J., Bialek, J. W. & Bumby, J. R. Power System Dynamics (John Wiley & Sons, 2008), 2 edn.
- [9] Ordacgi Filho, J. M. Brazilian blackout 2009: Blackout watch. Protection, Automation and Control World (2010). URL http://www.pacw.org/fileadmin/doc/MarchIssue2010/ Brazilian\_Blackout\_march\_2010.pdf.
- [10] Van Cutsem, T. Voltage instability: phenomena, countermeasures, and analysis methods. Proceedings of the IEEE 88, 208–227 (2000).
- [11] Rohden, M., Sorge, A., Timme, M. & Witthaut, D. Self-organized synchronization in decentralized power grids. *Physical Review Letters* 109, 064101 (2012).
- [12] Dobson, I. Complex networks: Synchrony and your morning coffee. Nature Physics 9, 133–134 (2013).
- [13] Motter, A. E., Myers, S. A., Anghel, M. & Nishikawa, T. Spontaneous synchrony in power-grid networks. *Nature Physics* 9, 191–197 (2013).
- [14] Menck, P. J., Heitzig, J., Kurths, J. & Joachim Schellnhuber, H. How dead ends undermine power grid stability. *Nature Communications* 5 (2014).
- [15] Rohden, M., Sorge, A., Witthaut, D. & Timme, M. Impact of network topology on synchrony of oscillatory power grids. *Chaos: An Interdisciplinary Journal of Nonlinear Science* 24 (2014).
- [16] Dörfler, F., Chertkov, M. & Bullo, F. Synchronization in complex oscillator networks and smart grids. Proceedings of the National Academy of Sciences 110, 2005–2010 (2013).
- [17] Skardal, P. S. & Arenas, A. Control of coupled oscillator networks with application to microgrid technologies. *Science Advances* 1 (2015).

- [18] Schultz, P., Heitzig, J. & Kurths, J. Detours around basin stability in power networks. New Journal of Physics 16, 125001 (2014).
- [19] Dewenter, T. & Alexander K, H. Large-deviation properties of resilience of power grids. New Journal of Physics 17, 015005 (2015).
- [20] Nishikawa, T. & Motter, A. E. Comparative analysis of existing models for power-grid synchronization. New Journal of Physics 17, 015012 (2015).
- [21] Wu, F. & Kumagai, S. Steady-state security regions of power systems. IEEE Transactions on Circuits and Systems 29, 703–711 (1982).
- [22] Kaye, R. & Wu, F. Analysis of linearized decoupled power flow approximations for steady-state security assessment. *IEEE Transactions on Circuits and Systems* **31**, 623–636 (1984).
- [23] Molzahn, D. K., Lesieutre, B. C. & DeMarco, C. L. A sufficient condition for power flow insolvability with applications to voltage stability margins. *IEEE Transactions on Power Systems* 28, 2592–2601 (2012).
- [24] Tamura, Y., Mori, H. & Iwamoto, S. Relationship between voltage instability and multiple load flow solutions in electric power systems. *IEEE Transactions on Power Apparatus and Systems* 102, 1115–1125 (1983).
- [25] Greene, S., Dobson, I. & Alvarado, F. L. Sensitivity of the loading margin to voltage collapse with respect to arbitrary parameters. *IEEE Transactions on Power Systems* 12, 262–272 (1997).
- [26] Schlueter, R. A., Costi, A. G., Sekerke, J. E. & Forgey, H. L. Voltage stability and security assessment. Tech. Rep. EPRI EL-5967 Project 1999-8, Division of Engineering Research, Michigan State University (1988).
- [27] Lof, P.-A., Andersson, G. & Hill, D. J. Voltage stability indices for stressed power systems. *IEEE Transactions on Power Systems* 8, 326–335 (1993).

- [28] Chiang, H.-D. & Jean-Jumeau, R. Toward a practical performance index for predicting voltage collapse in electric power systems. *IEEE Transactions on Power Systems* 10, 584–592 (1995).
- [29] Overbye, T. J. & Klump, R. P. Effective calculation of power system low-voltage solutions. *IEEE Transactions on Power Systems* 11, 75–82 (1996).
- [30] Ajjarapu, V. & Christy, C. The continuation power flow: a tool for steady state voltage stability analysis. *IEEE Transactions on Power Systems* 7, 416–423 (1992).
- [31] Overbye, T. J., Dobson, I. & DeMarco, C. L. Q-V curve interpretations of energy measures for voltage security. *IEEE Transactions on Power Systems* 9, 331–340 (1994).
- [32] Cañizares, C. A. Calculating optimal system parameters to maximize the distance to saddlenode bifurcations. *IEEE Transactions on Circuits and Systems I: Fundamental Theory and Applications* 45, 225–237 (1998).
- [33] Cañizares, C. A. (ed.). Voltage Stability Assessment: Concepts, Practices and Tools (IEEE-PES Power System Stability Subcommittee, 2002). Tech. Rep. PES-TR9.
- [34] Grijalva, S. & Sauer, P. W. A necessary condition for power flow Jacobian singularity based on branch complex flows. *IEEE Transactions on Circuits and Systems I: Fundamental Theory* and Applications 52, 1406–1413 (2005).
- [35] Grijalva, S. Individual branch and path necessary conditions for saddle-node bifurcation voltage collapse. *IEEE Transactions on Power Systems* 27, 12–19 (2012).
- [36] Thorp, J., Schulz, D. & Ilić-Spong, M. Reactive power-voltage problem: conditions for the existence of solution and localized disturbance propagation. *International Journal of Electrical Power & Energy Systems* 8, 66–74 (1986).
- [37] Bolognani, S. & Zampieri, S. On the existence and linear approximation of the power flow solution in power distribution networks. *IEEE Transactions on Power Systems* **31**, 163–172 (2015).

- [38] Dörfler, F. & Bullo, F. Novel insights into lossless AC and DC power flow. In IEEE Power & Energy Society General Meeting (Vancouver, BC, Canada, 2013).
- [39] Zimmerman, R. D., Murillo-Sánchez, C. E. & Thomas, R. J. MATPOWER: Steady-state operations, planning, and analysis tools for power systems research and education. *IEEE Transactions on Power Systems* 26, 12–19 (2011).
- [40] Capitanescu, F. & Van Cutsem, T. Unified sensitivity analysis of unstable or low voltages caused by load increases or contingencies. *IEEE Transactions on Power Systems* 20, 321–329 (2005).
- [41] Berman, A. & Plemmons, R. J. Nonnegative Matrices in the Mathematical Sciences (SIAM, 1994).

Acknowledgments: This work was supported in part by the National Science Foundation NSF CNS-1135819, by ETH Zürich funds, the SNF Assistant Professor Energy Grant #160573, and by the National Science and Engineering Research Council of Canada.

Author contributions: Research design, theoretical results, and numerics were performed by J.W.S.-P., with F.D. and F.B. supervising the project. All authors contributed to editing the manuscript.

Additional information: An extensive Supplementary information accompanies the online version of this paper; its organization is detailed in (Supplementary Note 1). Correspondence and requests for materials should be addressed to J.W.S.-P.

Competing financial interests: The authors declare no competing financial interests.

#### **Figure Legends**

Figure 1: Mechanical and energy interpretations of power flow. (a) An example power network with two generators (green) supplying power to three loads (red). Power demands  $(Q_1, Q_2, Q_3)$  are placed on the load nodes; (b) a mechanical analogy: a linear spring network placed in a potential field. The generator voltages (green) are "pinned" at constant values, while the load voltages (red) are masses "hanging" off the generators, their equilibrium values being determined by their weights (the power demands  $\mathbf{Q}_{\mathrm{L}} = (Q_1, Q_2, Q_3)$ ), the heights of the fixed generator voltages  $(V_4, V_5)$ , and by the stiffness of the spring network (the susceptance matrix **B**). Voltage collapse can occur when one of the masses crosses an appropriate collapse boundary curve; (c) Contour plot of energy function when  $Q_3 = 0$  and node 3 is eliminated via Kron reduction [13]. Since  $E(\mathbf{V}_{\mathrm{L}})$  contains logarithms, it tends to  $-\infty$  as either axis is approached. In a normalized system of units, the stable high-voltage equilibrium rests in a local minimum at (0.94, 0.94), while an unstable lowvoltage equilibrium sits at the saddle (0.68, 0.30). Voltage collapse occurs when these equilibria coalesce and the system trajectory diverges.

Figure 2: Sparsity patterns of network matrices for 57 node test case. (a) the stiffness matrix  $\mathbf{Q}_{\text{crit}}$  representing the auxiliary network. (b) The inverse stiffness matrix  $\mathbf{Q}_{\text{crit}}^{-1}$ . The 57 node network contains 50 loads and 7 generators. Nodes are sorted and grouped by connected components of the subgraph induced by  $\mathbf{Q}_{\text{crit}}$ , with connected components ordered from largest to smallest; nodes  $\{1, \ldots, 48\}$  are part of one large connected component, while nodes  $\{49, 50\}$  each constitute their own component. Color scale represents normalized values of the matrix elements, with dark blue being zero and red being one. Diagonal elements of  $\mathbf{Q}_{\text{crit}}$  are displayed in absolute value for clarity.

Figure 3: Stress testing of voltage stability condition for low power factor loading. The horizontal voltage axis is scaled by  $V_{\text{base}} = 345$  kV. The solid black trace is the numerically computed voltage magnitude at node four, while the dotted red trace is given explicitly by  $V_4^*(1 - \delta_-)$ , where  $\delta_-$  is determined as below (7). The stability margin  $\Delta$  is shown in dashed blue. When  $\Delta > 1$ ,  $\delta_-$  becomes undefined and the corresponding bound is no longer plotted.

Figure 4: Stress testing of voltage stability condition for high power factor loading. The horizontal voltage axis is scaled by  $V_{\text{base}} = 345 \text{ kV}$ . The solid black trace is the numerically computed voltage magnitude at node four, while the dotted red trace is given explicitly by  $V_4^*(1 - \delta_-)$ , where  $\delta_-$  is determined as below (7). The stability margin  $\Delta$  is shown in dashed blue.

Figure 5: Corrective action results for the reduced New England 39 node network. (a) Depiction of the reduced New England grid. Load nodes  $\{1, \ldots, 30\}$  are red circles, while generators  $\{31, \ldots, 39\}$  are green squares. Shunt capacitors are present at all load nodes, but shown explicitly at nodes 7, 8, and 9. (b) Results of corrective action study. Voltage profile  $V_i$  (black) and scaled voltages  $V_i/V_i^*$  (red), before (solid) and after (dashed) corrective action. All voltages were scaled by the grid's base voltage  $V_{\text{base}} = 345$  kV. Horizontal dashed lines are operational limits for  $V_i$  of  $\pm 5\%$  from base voltage. For clarity only nodes  $\{1, \ldots, 20\}$  are

plotted.

Test case	Condition	Exact Deviation	Predicted Deviation	Condition
(1000 instances)	Correctness	$(\delta_{ ext{exact}})$	$(\delta_{-})$	Accuracy
9 bus system	true	$5.50 \cdot 10^{-2}$	$5.52 \cdot 10^{-2}$	$3.56\cdot 10^{-3}$
14 bus system	true	$2.50 \cdot 10^{-2}$	$2.51 \cdot 10^{-2}$	$1.96 \cdot 10^{-3}$
RTS 24	true	$3.28 \cdot 10^{-2}$	$3.29 \cdot 10^{-2}$	$3.28 \cdot 10^{-3}$
30 bus system	true	$4.72 \cdot 10^{-2}$	$4.75 \cdot 10^{-2}$	$7.64 \cdot 10^{-3}$
New England 39	true	$5.95 \cdot 10^{-2}$	$5.99\cdot10^{-2}$	$5.97\cdot10^{-3}$
RTS '96 (2 area)	true	$3.44 \cdot 10^{-2}$	$3.45 \cdot 10^{-2}$	$3.81\cdot 10^{-3}$
57 bus system	true	$0.97 \cdot 10^{-1}$	$0.99 \cdot 10^{-1}$	$2.97\cdot 10^{-2}$
RTS '96 (3 area)	true	$3.57 \cdot 10^{-2}$	$3.58 \cdot 10^{-2}$	$3.94 \cdot 10^{-3}$
118 bus system	true	$2.68 \cdot 10^{-2}$	$2.69 \cdot 10^{-2}$	$3.63 \cdot 10^{-3}$
300 bus system	true	$1.32 \cdot 10^{-1}$	$1.36 \cdot 10^{-1}$	$3.03\cdot 10^{-2}$
Polish 2383 system	true	$4.03 \cdot 10^{-2}$	$4.06 \cdot 10^{-2}$	$8.55 \cdot 10^{-3}$

Numerical Testing of Theoretical Predictions

Table 1: Voltage stability condition applied to 11 test networks. Condition correctness is whether the implication  $\Delta = \|\mathbf{Q}_{crit}^{-1}\mathbf{Q}_{L}\|_{\infty} < 1 \implies \delta_{exact} \leq \delta_{-}$  holds for every network realization, where  $\delta_{-} = \frac{1}{2}(1 - \sqrt{1 - \Delta})$  and  $\delta_{exact}$  is determined numerically. Exact and predicted deviations are averaged values of the respective quantities over all realizations. Condition accuracy is calculated as  $(\delta_{-} - \delta_{exact})/\delta_{exact}$ , and averaged over 1000 randomized instances for each network, with 30% of generation (resp. 30% of load) randomized by 30% (resp. 50%) using a normal distribution centered around base conditions.

# **Supplementary Information**

# **Supplementary Figures**



Supplementary Fig. 1: Example of original and induced networks. (a) An example network with one generator (green square) and five loads (red circles); (b) The subgraph induced by the load nodes  $\mathcal{V}_L$ . Generator buses separate the induced load subgraph into disconnected components in which voltage stability can be assessed independently.



Supplementary Fig. 2: Locus of solutions to the one-dimensional power flow equation (20). The stable solution  $v^+$  lies on the top portion of the curve, deviating from the open-circuit voltage  $v^*$  by a small percentage  $\delta_-$ . The unstable solution lies on the bottom portion of the curve, deviating from  $v^*$  by a large percentage  $\delta_+$ .



Supplementary Fig. 3: Illustration of the construction leading to the parametric condition (31).



Supplementary Fig. 4: Visualization of Supplementary Theorem 1 when  $\Delta \in ]0, 1[$ . (a) The partitioning of load-space. The critical load profile which lies on the existence boundary is marked with a red star in (a), and leads to the voltage solution marked with a star in (b). The light shaded region above the diagonal line corresponds to the necessary solvability condition in Proposition 2. The dark shaded region is the convex hull of load profiles which satisfy  $\Delta = 4\delta_{\pm}(1 - \delta_{\pm})$ . (b) The partitioning of voltage-space. Red crosses ( $\times$ ) denote unstable power flow equilibria, while the green cross ( $\times$ ) indicates the stable equilibrium. The dark shaded region is the stability set  $\overline{S}(\delta_{-})$  in which the unique voltage-stable solution is guaranteed to exist, while the light shaded region is the open set of Supplementary Theorem 1 2), where solutions are forbidden. The Venikov index  $K_{\rm V} = \sqrt{1 - \Delta}$  provides a guaranteed bound between stable and unstable equilibria in voltage-space.

# Supplementary Notes

positive [2, 1].

## Supplementary Note 1 – Organization and Preliminaries

This supplementary information is organized as follows.

Supplementary Note 1 — Organization and Preliminaries — provides a table of contents for this supplementary information and establishes some mathematical notation.

Supplementary Note 2 — *Review of Explicit Voltage Stability Conditions* — reviews the parametric voltage stability conditions available in the literature.

Supplementary Note 3 — *Mathematical Models* — provides a detailed description of the considered power network models, including transmission grid, generator, and load modeling. We also describe the approximations which lead to the reactive power flow model considered in the main article.

Supplementary Note 4 — *Energy, Voltage Stability & The Power Flow Jacobian* — formally defines the concept of long-term voltage stability, and relates voltage stability of an operating point to the local minima of the energy function and to the non-singularity of the power flow Jacobian.

Supplementary Note 5 — Voltage Stability in Complex Power Networks — contains the mathematical analysis leading to the main result presented in the article. We offer interpretations and comments throughout along with several corollaries.

Supplementary Note 6 — Monotonicity of Stability Margins With Respect to Parameters: Results and Counterexamples — examines how variations in grid parameters influence the proposed stability margin of the grid.

Supplementary Note 7 — Voltage Stability Condition Incorporating Generator Injection Limits — presents a generalized version of our main result which accounts for generator reactive power limits.

Finally, Supplementary Methods provides additional details regarding the extensive numerical simulations presented in the main article.

Sets, vectors and matrices: Given a finite set  $\mathcal{V}$ , let  $|\mathcal{V}|$  denote its cardinality. The set  $\mathbb{R}$  (resp.  $\mathbb{R}_{\geq 0}$ ,  $\mathbb{R}_{>0}$ ) is the field of real (resp. nonnegative real, strictly positive real) numbers, and  $\mathbb{C}$  is the field of complex numbers. For  $x \in \mathbb{R}^n$ ,  $[x] \in \mathbb{R}^{n \times n}$  is the associated diagonal matrix. Given  $x, y \in \mathbb{R}^n$ , we write  $x \geq y$  if  $x_i \geq y_i$  for each  $i \in \{1, \ldots, n\}$ , and will occasionally write  $z \in [x, y]$  if  $x \leq z \leq y$ . Similarly we define x > y and  $z \in [x, y]$  in the obvious ways. We let  $\mathbb{1}_n$  and  $\mathbb{O}_n$  be the *n*-dimensional column vectors of unit and zero entries, with  $I_n$  the  $n \times n$  identity matrix. For nonempty sets  $\mathcal{K}_1$  and  $\mathcal{K}_2, \mathcal{K}_1 \setminus \mathcal{K}_2 = \{x \in \mathcal{K}_1 \mid x \notin \mathcal{K}_2\}$  is the set of elements in  $\mathcal{K}_1$  which do not also belong to  $\mathcal{K}_2$ . *M*-Matrices: A matrix  $A \in \mathbb{R}^{n \times n}$  is a Z-matrix if  $A_{ij} \leq 0$  for all  $i \neq j$ . The spectral radius  $\rho(A)$  of a real-valued matrix  $A \in \mathbb{R}^{n \times n}$  is  $\rho(A) = \max\{|\lambda|_{\mathbb{C}} \mid \det(\lambda I_n - A) = 0\}$ , where  $|x|_{\mathbb{C}}$  is the magnitude of  $x \in \mathbb{C}$ . A Z-matrix  $A \in \mathbb{R}^{n \times n}$  is an M-matrix if it can be expressed as  $A = sI_n - B$ , where  $B \in \mathbb{R}^{n \times n}$  has nonnegative elements and  $s \geq \rho(B)$ . If A is a nonsingular M-matrix, then the elements of  $A^{-1}$  are nonnegative [1]. Moreover, if the directed graph induced by the sparsity pattern of A is strongly connected, then A is irreducible and the elements of  $A^{-1}$  are all strictly

Geometry on the circle: The set  $\mathbb{S}^1$  is the unit circle, an angle is a point  $\theta \in \mathbb{S}^1$ , and an arc is a connected subset of  $\mathcal{S}^1$ . The geodesic distance between two angles  $\theta_1, \theta_2 \in \mathcal{S}^1$ , denoted by  $|\theta_1 - \theta_2|$ ,

is the minimum length of the counter-clockwise and clockwise arcs connecting  $\theta_1$  and  $\theta_2$ .

The  $\infty$ -Norm and Unit Balls: The  $\infty$ -norm of  $x \in \mathbb{R}^n$  is given by  $||x||_{\infty} = \max_{i \in \{1,...,n\}} |x_i|$ , and the induced norm of a matrix  $A \in \mathbb{R}^{n \times n}$  is  $||A||_{\infty} = \max_{i \in \{1,...,n\}} \sum_{j=1}^{n} |A_{ij}|$ . It holds that  $\rho(A) \leq ||A||_{\infty}$ . The associated closed unit ball is defined by  $\overline{\mathcal{B}}_{\infty}(\delta) \triangleq \{x \in \mathbb{R}^n \mid ||x||_{\infty} \leq \delta\}$ , with  $\mathcal{B}_{\infty}(\delta)$  being its interior.

Nonlinear Equations: For a smooth map  $f : \mathbb{R}^n \to \mathbb{R}^n$ , a solution  $x^* \in \mathbb{R}^n$  of  $f(x) = \mathbb{O}_n$  is a regular solution if the Jacobian matrix  $\frac{\partial f}{\partial x}(x^*)$  is nonsingular. For a compact set  $X \subset \mathbb{R}^n$ , a map  $f : X \to X$  is a contraction map on X if there exists an  $\alpha \in [0, 1[$  (the contraction rate) and a norm  $\|\cdot\|$  such that for any  $x, y \in X$ ,  $\|f(x) - f(y)\| \leq \alpha \|x - y\|$ . If in addition X is convex and f is continuously differentiable, then f is a contraction map on X with contraction rate  $\alpha$  if  $\|\frac{\partial f}{\partial x}(x)\|_{\text{ind}} < \alpha$  for each  $x \in X$ , where  $\|\cdot\|_{\text{ind}}$  is the matrix norm induced by the vector norm  $\|\cdot\|$ .

#### Supplementary Note 2 – Review of Explicit Voltage Stability Conditions

In [3, 4, 5] the completely decoupled ( $\gamma = 0$  in Assumption 3) power flow equations were analyzed using fixed point techniques, resulting in vector-valued sufficient conditions of the form  $h_i(V^{\min}) \leq$  $Q_i \leq h_i(V^{\max})$  for all  $i \in \mathcal{L}$ , where  $V^{\min}$  and  $V^{\max}$  are upper and lower bounds on the nodal load voltages. No guarantees are given on uniqueness of the stable equilibrium, the analysis is not clearly related to the network structure, and the Jacobian must satisfy a diagonal dominance condition, which is known to be restrictive and often violated when including line charging capacitors and capacitive shunts [6]. Moreover, [3] requires an unrealistic tiering assumption on the network structure, where all load (PQ) buses are at most once-removed from a generator (PV) bus. In [6] the network stiffness was quantified by the product of the smallest eigenvalue (in magnitude) of the admittance matrix  $|\lambda_1(B_{LL})|$  and a desired lower bound on the voltage at any load bus, with the severity of loading captured by the largest load  $||Q_L||_{\infty} = \max_{i \in \mathcal{L}} |Q_i|$ . This conservative sufficient condition heavily underestimates the network stiffness while overestimating the severity of loading, and does not take into account the interaction between network structure and the spatial distribution of load. The recent work [7] shows that a similar condition suffices for solvability of the coupled active/reactive power flow equations, but in distribution networks with a single generator. Other results on power flow solvability and security [8, 9, 10, 11] provide only necessary solvability conditions, or use constant-impedance/current load models, and are therefore unable to assess voltage collapse.

The papers [12, 13] provide branch-wise necessary conditions for voltage collapse, showing that voltage collapse can occur only after at least one branch of the network is saturated past a limit, termed the *static transfer stability limit*. While this is an insightful analysis framework, evaluating the transfer limit conditions requires knowledge of branch-wise power flows and voltage magnitudes, that is, the conditions are checked based on the output of a power flow program. In contrast, our goal is to work directly from the given data of the problem (topology, impedances, loading, and generator voltages) and develop conditions which guarantee the existence of a power flow solution and characterize its robustness margins.

## Supplementary Note 3 – Mathematical Models

In this section we introduce the relevant power network models for the transmission network, generators, and loads. Our focus is on high-voltage power transmission networks.

#### **Transmission Network Modeling**

Throughout this work we consider a connected, phase-balanced power network operating in sinusoidal quasisteady-state. The network is modeled as a weighted and undirected graph  $G(\mathcal{V}, \mathcal{E}, Y)$ with nodes (or *buses*)  $\mathcal{V}$ , edges (or *branches*)  $\mathcal{E} \subset \mathcal{V} \times \mathcal{V}$ , and complex edge weights (or *admittances*)  $y_{ij} \in \mathbb{C}$ . The network has two distinct types of buses: loads  $\mathcal{L}$  and generators  $\mathcal{G}$ , such that  $\mathcal{V} = \mathcal{L} \cup \mathcal{G}$ . For notational simplicity, we set  $n \triangleq |\mathcal{L}|, m \triangleq |\mathcal{G}|$  and assume  $n, m \ge 1$ . To each bus we associate a phasor voltage  $U_i = V_i e^{j\theta_i} \in \mathbb{C}$  where  $V_i \ge 0$  is the voltage magnitude and  $\theta_i \in \mathbb{S}^1$  is the voltage angle, and a complex power injection  $S_i = P_i + jQ_i$ .

Transmission lines are represented using the standard lumped parameter  $\Pi$ -model, which allows for the inclusion of inductive/capactive shunts, tap-changing transformers, and line charging capacitors [14]. We encode the weights and topology in the bus admittance matrix  $Y \in \mathbb{C}^{(n+m)\times(n+m)}$ , with elements  $Y_{ij} = -y_{ij}$  and  $Y_{ii} = -\sum_{j=1}^{n+m} y_{ij} + y_{\text{shunt},i}$ , where  $y_{\text{shunt},i}$  is the shunt element at bus *i*. The conductance matrix G and susceptance matrix B are defined by G = Re(Y) and B = Im(Y). For the 100+ kV transmission-level networks we consider, the admittances of the transmission lines are dominantly inductive. The real part of the bus admittance matrix is therefore negligible, and  $Y \simeq jB$  [14]; see [15, 16] for studies concerning lossy models.

For later use we summarize for properties of the susceptance matrix.

**Fact 1** (Properties of Susceptance Matrix [5]). If the network contains no phase-shifting transformers and the transmission lines are not overcompensated by series capacitors, then for all  $i, j \in \mathcal{V}$ 

- (i) Symmetry:  $B_{ij} = B_{ji}$ ;
- (*ii*) Sign Structure:  $B_{ij} \ge 0$ , with  $B_{ij} > 0$  if and only if  $\{i, j\} \in \mathcal{E}$ ;
- (iii) Self-susceptances:  $B_{ii} = -\sum_{j=1, j \neq i}^{n+m} B_{ij} + B_{i,\text{shunt}}$  for all  $i \in \mathcal{V}$ , where  $B_{i,\text{shunt}}$  is the shunt element at node *i*. The shunt at node *i* is capacitive if  $B_{i,\text{shunt}} > 0$ , and inductive if  $B_{i,\text{shunt}} < 0$ .

Partitioning the susceptance matrix according to load and generators as

$$B = \begin{pmatrix} B_{LL} & B_{LG} \\ B_{GL} & B_{GG} \end{pmatrix}, \tag{1}$$

our results to follow require the following weak assumptions on the sub-matrix  $B_{LL}$  (sometimes referred to as a grounded susceptance matrix) and the network topology.

Assumption 1 (Susceptance Matrix). The (negative) grounded susceptance matrix  $-B_{LL} \in \mathbb{R}^{n \times n}$ is a nonsingular *M*-matrix.

**Assumption 2** (Connected Subgraph). The subgraph of  $G(\mathcal{V}, \mathcal{E}, B)$  induced by the load nodes  $\mathcal{L}$  is connected.

Assumption 1 is universally satisfied in practical networks [6, Section III], and always satisfied in the absence of line charging and shunt capacitors due to diagonal dominance [17]. Assumption 2 may be taken without loss of generality when studying the fundamental physics of reactive power flow in transmission networks, as the voltage-regulated generator buses electrically isolate groups of load buses from one another (Supplementary Fig. 1). Note that under Assumptions 1 and 2,  $-B_{LL}$  is a symmetric, irreducible nonsingular *M*-matrix, and hence all elements of  $-B_{LL}^{-1}$  are strictly positive [2, 1].

Applying Kirchoff's and Ohm's Laws to the network, the vector of nodal complex power injections  $S = (S_1, \ldots, S_{n+m})$  is related to the susceptance matrix B and the vector of nodal complex voltages  $U = (U_1, \ldots, U_{n+m})$  by  $S = [U] \cdot \operatorname{conj}(YU) = [U] \cdot \operatorname{conj}(jBU)$ , where  $\operatorname{conj}(x)$  is the element-wise complex conjugation of the vector  $x \in \mathbb{C}^{n+m}$ . In components, the real and imaginary parts of the product  $[U] \cdot \operatorname{conj}(jBU)$  define the power flow functions  $g_i, h_i : \mathbb{R}^{n+m} \times \mathbb{T}^{n+m} \to \mathbb{R}$ , which can be quickly calculated to be

$$g_i(V,\theta) \triangleq \sum_{j=1}^{n+m} V_i V_j B_{ij} \sin(\theta_i - \theta_j), \qquad (2a)$$

$$h_i(V,\theta) \triangleq -\sum_{j=1}^{n+m} V_i V_j B_{ij} \cos(\theta_i - \theta_j).$$
(2b)

Physically,  $g_i$  and  $h_i$  are the *active power* and *reactive power* injected at node  $i \in \mathcal{V}$  when the voltage magnitudes and angles are  $V = (V_1, \ldots, V_{n+m})$  and  $\theta = (\theta_1, \ldots, \theta_{n+m})$ .

#### **Generator Modeling**

As standard in power flow analysis, the synchronous generators at nodes  $\mathcal{G}$  are modeled as PV buses, at which the active power injections  $P_i \in \mathbb{R}$  are fixed by the prime movers and voltage magnitudes  $V_i > 0$  are tightly regulated by Automatic Voltage Regulators (AVR). This regulation is always achieved under normal operating conditions, when field and stator currents have not reached their operational limits [18, Chapter 3.3.5]. In the saturated case, the generator reaches its operational reactive power limit. One approach to handling this saturation is to change the generator model - reactive power output is held fixed at the operational maximum, and the terminal voltage is allowed to float. In this modeling framework, the generator behaves as a negative constant-power load [19, 20]. A downside of this approach is that the specific limits encountered depend on the direction of the loading vector in the space of parameters. In Supplementary Note 6 we take a different approach and instead present a condition under which generators meet their reactive power overexcitation limits, thereby avoiding this issue. Our results can also be extended to include distributed generation interfaced through power inverters with voltage-droop controllers [21, 22] or microgenerators which inject constant amounts of current or power (modeled as negative loads). Moreover, our results are not dependent on the inclusion of generator dynamics due to time-scale separation: the transient instabilities associated with generator swing and flux decay dynamics occur on the order of seconds [14], while the voltage collapse phenomena we consider occur over minutes [23].

#### Load Modeling

Load models characterize the power consumed by individual or aggregate loads, while taking into account relevant voltage and frequency-dependent behavior and/or dynamic phenomena. For studying voltage collapse, we are concerned only with the long-term feasibility of the network operating point, and therefore with no loss of generality may restrict ourselves to static load models [24, 25]. As such, the load models we consider have no internal state variable, and the active and reactive power demands  $P_i, Q_i \in \mathbb{R}$  at load node  $i \in \mathcal{L}$  are expressed as static functions  $P_i(V_i)$  and  $Q_i(V_i)$ of the local bus voltage magnitude. Kirchhoff's Current Law requires that power injections given by (2a)–(2b) equal the power demands  $P_i(V_i)$  and  $Q_i(V_i)$  at each node, yielding the power flow equations

$$P_i(V_i) = g_i(V,\theta), \quad i \in \mathcal{L} \cup \mathcal{G},$$
(3a)

$$Q_i(V_i) = h_i(V,\theta), \quad i \in \mathcal{L}.$$
(3b)

We focus on the *n* reactive power flow equations (RPFE) (3b); see [26, 27] and the references therein for detailed analyses of the active power flow equations (3a). While in the main article we considered constant power loads  $Q_i(V_i) = Q_i$ , here we consider the more general "ZIP" load model [14]

$$Q_i(V_i) = b_{\text{shunt},i} V_i^2 + I_{\text{shunt},i} V_i + Q_i, \quad i \in \mathcal{L},$$
(4)

which approximates the steady-state behavior of a wide class of practical loads. The model (4) is a concatenation of three separate loads:

- (a) "Z"-load: a shunt connection to ground through a susceptance  $b_{\text{shunt},i} \in \mathbb{R}$ .
- (b) "I"-load: a constant current device injecting a reactive current  $I_{\text{shunt},i} \in \mathbb{R}$ . The current is *leading* if  $I_{\text{shunt},i} > 0$  and *lagging* if  $I_{\text{shunt},i} < 0$ ;
- (c) "P"-load: a constant power device, injecting fixed reactive power  $Q_i \in \mathbb{R}$ . The load is called *capacitive* if  $Q_i > 0$ , and *inductive* if  $Q_i < 0$ .

As we have already allowed for shunt loads in the admittance matrix B, we will without loss of generality set  $b_{\text{shunt},i} = 0$  in (4) for all  $i \in \mathcal{L}$ . In practice, the literature has established that the constant-power load model (c) is the most relevant one for steady-state security analysis [28], and the one most relevant from the perspective of both classic [18] and modern [11, 29] power system operation. This "stiff" (i.e., voltage independent) behavior may arise due to on-load tap-changing transformers maintaining a constant voltage at the load supply point, or as an estimate of aggregate load as in utility forecasts [28]. It can be shown that when the constant-power portion of the load model (4) is zero, the reactive power balance (3b) degenerates into a system of linear equations in the voltage magnitudes [30, 9, 10]. Moreover, it has been noted that constant power load modeling is generic for feasibility studies in the sense that it tightly captures the transfer limitations of the network, and allows the study of whether an operating point exists for any static or dynamic load model, when the load consumes a specified amount of power [31]. If a feasible operating point can be determined, it can then be used as part of the initial conditions for further numerical dynamic stability studies. See [32, 33, 9, 21] for additional information and analysis.

#### Power Angle Decoupling

In practice, typical solutions to the power flow equations (3a)–(3b) have the property that  $|\theta_i - \theta_j| \leq \gamma$  for each edge  $\{i, j\} \in \mathcal{E}$  and some small value of  $\gamma > 0$ , and that load voltage magnitudes  $V_i$  are roughly equal to the generator voltage level. This leads to an important (in)sensitivity relationship for reactive power flow, which we now describe. Evaluating the derivative of the reactive power injection (2b) around such a solution, we find that

$$\left|\frac{\partial h_i}{\partial \theta_k}\right| = V_i V_k B_{ik} |\sin(\theta_i - \theta_k)| \le V_i V_j B_{ij} \sin(\gamma) \simeq 0, \qquad k \neq i,$$
(5a)

$$\left|\frac{\partial h_i}{\partial V_k}\right| = V_i B_{ij} |\cos(\theta_i - \theta_k)| \ge V_i B_{ik} \cos(\gamma) \simeq V_i B_{ik}, \qquad k \neq i.$$
(5b)

with similar formulas holding for the diagonal elements. It follows that the reactive power injections (2b) are insensitive to changes in the power angles  $\theta_i - \theta_j$  around such solutions, and that active power enters through second order effects. It is therefore common to study (3b) under a *decoupling* assumption, in which the power angles are treated as parameters [6, 30], or even assumed to be negligible [4, 5]. We formalize these qualitative statements into the following technical assumption.

**Assumption 3** (Power Angle Decoupling). The power angles are constant and such that  $|\theta_i - \theta_j| \leq \gamma$  for some value  $\gamma \in [0, \pi/2[$  and for all branches  $\{i, j\} \in \mathcal{E}$  of the network.

See [5] and Ref. 14 of [30] for analysis on the error introduced by total decoupling, that is, the extreme case  $\gamma = 0$  in Assumption 3. In practical networks, a typical value of  $\gamma$  in Assumption 3 would be 5°. Under Assumption 3, from the form of (2b) it is clear that we can define an *effective susceptance matrix* by grouping the original line susceptances  $B_{ij}$  and the power angle terms  $\cos(\theta_i - \theta_j)$ . The properties of the original susceptance matrix from Fact 1 also hold for the effective susceptance matrix, and one may verify that if Assumption 1 holds, then the corresponding submatrix of the effective susceptance matrix is also a nonsingular *M*-matrix. To keep notation simple, in what follows we will denote by *B* the effective susceptance matrix with elements  $B_{ij} \cos(\theta_i - \theta_j)$  for  $i, j \in \mathcal{V}$ . With this notation, the power flow equation (3b) becomes

$$Q_i + V_i I_{\text{shunt},i} = -\sum_{j=1}^{n+m} V_i B_{ij} V_j , \qquad i \in \mathcal{L} .$$
(6)

#### The Reactive Power Flow Equations

In vector notation, the reactive power flow equation (6) can be written as

$$Q_L + [V_L]I_{\text{shunt}} = -[V_L] \left( B_{LL}V_L + B_{LG}V_G \right) \,, \tag{7}$$

where  $Q_L = (Q_1, \ldots, Q_n)$  is the vector of constant power load demands,  $I_{\text{shunt}} = (I_{\text{shunt},1}, \ldots, I_{\text{shunt},n})$ is the vector of constant current load demands,  $V_L = (V_1, \ldots, V_n) > \mathbb{O}_n$  is the vector of load voltage magnitudes,  $V_G = (V_{n+1}, \ldots, V_{n+m}) > \mathbb{O}_m$  is the vector of constant generator voltage magnitudes,  $[V_L]$  is the diagonal matrix of load voltages. Equivalently, we may write

$$Q_L = -[V_L]B_{LL}(V_L - V_L^*),$$
(8)

where we have defined the open-circuit load voltages  $V_L^* \in \mathbb{R}^n$  by

$$V_L^* \triangleq -B_{LL}^{-1}(B_{LG}V_G + I_{\text{shunt}}).$$
<sup>(9)</sup>

The terminology open-circuit means that  $V_i^*$  is the voltage measured at load bus  $i \in \mathcal{L}$  when the constant-power loads are open-circuited, that is,  $Q_1 = Q_2 = \cdots = Q_n = 0$ . We make the following standing assumption regarding the constant current portion  $I_{\text{shunt}}$  of the load.

Assumption 4 (Shunt Current Restriction). The shunt currents are not overly inductive. In particular,  $B_{LG}V_G + I_{\text{shunt}} > \mathbb{O}_n$ .

Assumption 4 always holds if the loads draw capacitive currents  $(I_{\text{shunt}} \geq 0_n)$ , and is always met in practical networks. This assumption leads to positive open-circuit voltages.

**Lemma 1** (Open-Circuit Voltages). Under Assumption 4, the open-circuit load voltages are strictly positive. That is,  $V_L^* > \mathbb{O}_n$ .

*Proof:* By Assumptions 1 and 2, the open-circuit voltages (9) are well defined and each element of  $-B_{LL}^{-1}$  is positive. Since  $B_{LG}V_G + I_{\text{shunt}} > \mathbb{O}_n$ , every element of (9) is therefore strictly positive.  $\Box$ 

Equation (8) is our preferred formulation of the RPFE (3b)–(4) since it highlights the tendency of the load voltages  $V_L$  to align with their open-circuit values  $V_L^*$ .

## Supplementary Note 4 – Energy, Voltage Stability & The Power Flow Jacobian

The term *voltage stability* has been appropriated over decades of research to refer to many different static and/or dynamic stability concepts, ranging orders of magnitude in time-scales. Herein we make use of the long-term quasi static notion of voltage stability [34, 35], which corresponds to the way the high-voltage solution of a power network should change under small load perturbations during regular operation. This is the notion of stability most relevant for guarding against static voltage instability collapse.

**Definition 1** (Local Voltage Stability). A regular solution  $V_L \in \mathbb{R}^n$  of the RPFE (8) is

(i) locally voltage-stable if for each pair of load buses  $i, j \in \mathcal{L}$ ,

$$\frac{\partial V_i}{\partial Q_j} > 0\,,\tag{10}$$

(ii) voltage-unstable if it is not locally voltage-stable.

Since a decreasing value of  $Q_j$  in (10) corresponds to an *increasing inductive load*, voltage stability is an "increasing load, decreasing voltage" condition. Definition 1 is the stability definition implicitly used when discussing stability margins derived from Jacobian-based voltage stability indices, and is the relevant stability concept at long time-scales on the order of minutes [23, 36]. Long-term voltage stability is time-scale separated from instabilities induced by fast generator or load dynamics, and can therefore be studied separately [28].

The energy function introduced in the main article is particularly useful for understanding voltage stability as in Definition 1. The following result relates the energy function, voltage stability, and the Jacobian matrix of the power flow equation.

**Lemma 2** (Energy, Stability, & The Power Flow Jacobian). Consider the reactive power flow equation (6), its Jacobian matrix  $J(V_L) \in \mathbb{R}^{n \times n}$  being given by

$$J(V_L) = [V_L]B_{LL} + [B_{LL}(V_L - V_L^*)], \qquad (11)$$

and the energy function  $E: \mathbb{R}^n_{>0} \to \mathbb{R}$  defined by

$$E(V_L) = \frac{1}{2} \sum_{i=1}^{n} \sum_{j=i+1}^{n+m} B_{ij} (V_i - V_j)^2 - \sum_{i=1}^{n} \left( \frac{1}{2} \kappa_i V_i^2 + I_{\text{shunt},i} V_i + Q_i \ln(V_i) \right) , \qquad (12)$$

where  $\kappa_i \triangleq \sum_{j=1}^{n+m} B_{ij}$ . Suppose  $V_L > \mathbb{O}_n$  is a regular solution of the RPFE (6). Then the following statements are equivalent:

- (i)  $V_L$  is a local minimum of the energy function (12);
- (ii)  $V_L$  is locally voltage-stable in the sense of Definition 1;
- (iii) the Jacobian  $J(V_L)$  given by (11) is Hurwitz.

*Proof:* (i)  $\iff$  (iii) : The critical points of  $E(V_L)$  satisfy  $\partial E/\partial V_L = \mathbb{O}_n^T$ , or in components for  $k \in \mathcal{L}$ 

$$\frac{\partial E}{\partial V_k} = 0 = \sum_{j=1}^{n+m} B_{kj} (V_k - V_j) - \kappa_k V_k - I_{\text{shunt},k} - \frac{Q_k}{V_k} \,. \tag{13}$$

After substituting for  $\kappa_k$  and simplifying, this becomes

$$0 = -Q_k - I_{\text{shunt},k} V_k - V_k \sum_{j=1}^{n+m} B_{kj} V_j , \qquad (14)$$

which is the RPFE (6). It follows that the critical points of (12) are in one-to-one correspondence with the solutions of (6). Some simple calculations show that the components of the Hessian matrix  $H(V_L)$  of  $E(V_L)$  are given by

$$H_{k\ell}(V_L) = \frac{\partial^2 E}{\partial V_k \partial V_\ell} = -B_{k\ell} - \delta_{k\ell} \frac{Q_k}{V_k^2}, \qquad k, \ell \in \mathcal{L},$$
(15)

where  $\delta_{k\ell} = 1$  if  $k = \ell$ , and is zero otherwise. Substituting for  $Q_k$  from the power flow equation (6), we arrive at

$$H_{k\ell}(V_L) = -B_{k\ell} - \delta_{k\ell} \frac{1}{V_k} \left( I_{\text{shunt},k} + \sum_{j=1}^{n+m} B_{kj} V_j \right),$$
(16)

which in matrix notation reads as

$$H(V_L) = -B_{LL} - [V_L]^{-1} [B_{LL}V_L + B_{LG}V_G + I_{\text{shunt}}]$$
(17a)

$$= -B_{LL} - [V_L]^{-1} [B_{LL}(V_L - V_L^*)], \qquad (17b)$$

where we have used (9). By comparison, we see that the Hessian  $H(V_L)$  is exactly  $-[V_L]^{-1}$  times the Jacobian matrix (11) of the RPFE (8). It follows that the Hessian matrix is positive definite if and only if the Jacobian (11) is Hurwitz.

 $(iii) \Longrightarrow (ii)$ : By definition the Jacobian matrix  $J(V_L)$  relates infinitesimal changes in nodal voltage to corresponding changes power injections via

$$\frac{\partial Q_L}{\partial V_L} = -J(V_L) \,. \tag{18}$$

The matrix representation (11) can be obtained from (8), either by a calculation in components or via standard matrix identities. Note from (11) that for  $i, j \in \mathcal{L}$ ,  $J_{ij}(V_L) = V_i B_{ij} \geq 0$ . Thus,  $-J(V_L)$ is a Z-matrix. Defining the symmetric matrix  $M \triangleq B_{LL} + [V_L]^{-1}[B_{LL}(V_L - V_L^*)]$ , note that we may write  $J(V_L) = [V_L]M$ . Since  $V_L > \mathbb{O}_n$ , the generalized Courant-Fischer Theorem [37] then implies that all eigenvalues of  $J(V_L)$  are real. So  $-J(V_L)$  is a Z-matrix with real eigenvalues, and it follows then from [2, Item  $C_9$ ] that  $J(V_L)$  is Hurwitz if and only if  $-J(V_L)$  is a nonsingular M-matrix. Moreover, these equivalent conditions hold true if and only if the inverse matrix  $-J(V_L)^{-1}$  exists and has nonnegative elements [2, Item  $F_{15}$ ]. By Assumption 2 it holds that  $J(V_L)$  is irreducible, so  $J(V_L)$  is in fact Hurwitz if and only if  $-J(V_L)^{-1}$  exists and has strictly positive elements [1]. Since  $V_L$  is a regular solution, the Inverse Function Theorem [38, Chapter 9] states that there exists an open neighborhood  $\mathcal{U}$  around  $V_L$  (resp. an open neighborhood  $\mathcal{W}$  around  $Q_L$ ) and a smooth function  $G: \mathcal{W} \to \mathcal{U}$  such that  $V_L = G(Q_L)$  for all  $Q_L \in \mathcal{W}$ . Moreover, the Jacobian of G satisfies

$$\frac{\partial G}{\partial Q_L} = \frac{\partial V_L}{\partial Q_L} = -J(V_L)^{-1}, \qquad (19)$$

where in the last equality we used the fact that  $Q_L$  appears linearly in (8). Since  $J(V_L)$  is Hurwitz, each element of  $-J(V_L)^{-1}$  is strictly positive, and we conclude that  $V_L$  is locally voltage-stable. (*ii*)  $\Longrightarrow$ (*iii*) : Proceed by contraposition and suppose that  $J(V_L)$  is not Hurwitz. Then by the set of implications preceding sufficiency, either a) there exists  $i, j \in \mathcal{L}$  such that the *ij*th element of  $-J(V_L)^{-1}$  is nonpositive, or b)  $J(V_L)^{-1}$  does not exist. In the first case, this means precisely that  $\partial V_i/\partial Q_j \leq 0$ , so  $V_L$  is by definition voltage-unstable. The second case in which  $J(V_L)$  is singular cannot occur, because  $V_L$  is a regular solution.

**Remark 1** (The Energy Function & Dynamic Stability). Voltage stability as considered in Definition 1 is consistent with local exponential stability of any dynamic load model which attempts to regulate power consumption to a constant value by demanding additional current under a drop in terminal voltage [28]. A simple example of this is the dynamic shunt susceptance model [33]  $\dot{b}_{shunt,i} = Q_i - b_{shunt,i}V_i^2$ , where the shunt susceptance  $b_{shunt,i}$  at node  $i \in \mathcal{L}$  is dynamically adjusted to achieve a constant power injection  $Q_i$ . More generally, such models include induction motors, load tap changers, and thermostatically controlled loads [33]. The local minimum of the energy function is clearly locally exponentially stable for an assortment of associated load dynamics, such as gradient  $\beta \dot{V}_L = -\nabla E(V_L)$ , or damped second-order dynamics  $\alpha \ddot{V}_L = -\beta \dot{V}_L - \nabla E(V_L)$  [39]. Static voltage stability is also relevant for slowly changing load profiles, where the fast stable load dynamics adiabatically track the network operating point (should it exist). Indeed, as Pal notes in [24], "For loads with slow dynamics, the stability limit will occur at the same point as the maximum power [transmission capacity] determined from a power flow analysis." For more general dynamic load models, our results can be interpreted as necessary for local dynamic stability, as the existence of a network operating point is an obvious prerequisite [40].

#### Supplementary Note 5 – Voltage Stability in Complex Power Networks

#### Single Load Example

To build intuition for our analysis in the case of complex networks, we present the results for the classic problem of a single generator feeding a single constant power load. For n = 1, the RPFE (8) is a single quadratic equation, and the necessary and sufficient condition for the existence of a solution follows immediately [33, Section 2.2.3].

**Proposition 1** (Condition for Single Load). Consider the RPFE (8) for a single load (n=1)

$$0 = q + bv(v - v^*), (20)$$

where b < 0,  $v^* > 0$ , and let  $q_{\text{crit}} \triangleq \frac{1}{4}b(v^*)^2 < 0$ . The following statements are equivalent:

- (i) Small Loading:  $\Delta = q/q_{\rm crit} < 1$ ;
- (ii) High-Voltage Solution: There exists a unique voltage-stable solution  $v^+$  to the RPFE (20) such that

$$\frac{|v^+ - v^*|}{v^*} = \delta_- < \frac{1}{2}; \tag{21}$$

(ii) Low-Voltage Solution: There exists a unique voltage-unstable solution  $v^-$  to the RPFE (20) such that

$$\frac{|v_{-} - v^{*}|}{v^{*}} = \delta_{+} > \frac{1}{2}.$$
(22)

Moreover, if any of the above statements are true, then  $\delta_{-}, \delta_{+}$ , and  $\Delta$  are related by

$$\delta_{\pm} = \left(1 \pm \sqrt{1 - \Delta}\right) / 2. \tag{23}$$

Proposition 1 shows that a stable high-voltage solution exists only for loads which are less inductive than the critical inductive load  $q_{\text{crit}}$ . Graphically, the situation is illustrated in Supplementary Fig. 2. Note that even in this simple scenario, the solution space of the RPFE is multi-valued. When  $q = q_{\text{crit}}$ , the solutions  $v^+$  and  $v^-$  coalesce at  $v^*/2$  and vanish via saddle-node bifurcation [25]. In this simple one-dimensional case, we can derive a parametric formula for the Venikov index, given by [41, 42, 18]

$$k_{\rm V} \triangleq \frac{v^+ - v^*/2}{v^*/2} = \sqrt{1 - |\Delta|} \,.$$
 (24)

As one may deduce from examining Supplementary Fig. 2, the Venikov index  $k_{\rm V}$  measures the distance between the high-voltage solution  $v_L^+$  and the low-voltage solution  $v_L^-$ , and thus gives an analytic measure of proximity to collapse.

#### **Proof of Main Result for Complex Networks**

The following simple necessary condition for solvability of (8) is inspired by the observations from Proposition 1.

**Proposition 2** (Necessary Feasibility Condition). Consider the decoupled reactive power flow equation (8), and define the critical load matrix  $Q_{\text{crit}} \in \mathbb{R}^{n \times n}$  by

$$Q_{\rm crit} \triangleq \frac{1}{4} [V_L^*] B_{LL} [V_L^*] \,. \tag{25}$$

If a solution to (8) exists, then

$$\frac{\mathbb{1}_n^T Q_L}{\mathbb{1}_n^T Q_{\text{crit}} \mathbb{1}_n} \le 1.$$
(26)

*Proof:* Defining a new variable  $z \triangleq V_L - \frac{1}{2}V_L^*$  and substituting for  $V_L$  in (8), we obtain the equivalent reformulation

$$Q_L = Q_{\rm crit} \mathbb{1}_n - \frac{1}{2} [V_L^*] B_{LL} z + \frac{1}{2} [z] B_{LL} V_L^* - [z] B_{LL} z \,.$$
(27)

A necessary condition for the power flow equation(27) to hold true is that the sum over all equations holds true. Performing the sum (equivalently, left-multiplying by  $\mathbb{1}_n^T$ ), the cross terms cancel and we obtain

$$\mathbb{1}_n^T Q_L = \mathbb{1}_n^T Q_{\text{crit}} \mathbb{1}_n - z^T B_{LL} z \,.$$
<sup>(28)</sup>

Since  $-B_{LL}$  is a symmetric nonsingular *M*-matrix (Assumption 1),  $B_{LL}$  is negative definite. Hence  $z^T B_{LL} z \leq 0$  for all  $z \in \mathbb{R}^n$  and the result follows.

We refer to [11] for an alternative proof of Proposition 2. We note that the necessary voltage stability condition (26) is also *tight*, as it holds with equality when  $Q_L = Q_{\text{crit}} \mathbb{1}_n$ , and a comparison with Proposition 1 shows that (26) is necessary and sufficient for a single load. Geometrically, the necessary condition of Proposition 2 restricts the vector of loads  $Q_L$  to a half-space. A downside of this necessary condition is that it provides only an aggregate bound on the load, and does not take into account how the load is distributed throughout the network in relation to voltage-regulated points, shunt capacitors, and so forth.

The following closed subset of voltage-space will help us quantify the area where desirable solutions to (8) should exist. Using the open-circuit voltages  $V_L^*$  defined in (9), for  $\delta \in [0, 1]$ , define the compact, convex and partially-ordered *stability set* by

$$\overline{\mathcal{S}}(\delta) \triangleq \left\{ V_L \in \mathbb{R}^n_{\geq 0} \mid (1-\delta) V_L^* \le V_L \le (1+\delta) V_L^* \right\},\tag{29}$$

with  $S(\delta)$  being its interior. If  $V_L \in \overline{S}(\delta)$ , then  $|V_i - V_i^*| / V_i^* \leq \delta$  for each component *i*, and thus  $\delta$  is simply a percentage deviation from the open-circuit voltage level.

**Remark 2** (The Stability set & The Per-Unit System). From the definition of our stability set in (29), the reader may be tempted to draw a one-to-one correspondence between the scaled voltages  $V_i/V_i^*$  ( $i \in \mathcal{L}$ ) and the classic per-unit measurement system used by power engineers, where all voltage values in the network are scaled by uniform base voltage  $V_i/V_{\text{base}}$ . We strongly caution against drawing this equivalence. While the base voltage  $V_{\text{base}}$  is constant and uniform, the opencircuit voltages  $V_i^*$  defined in (9) vary bus-to-bus, and take into account non-uniform generator voltages, network topology, shunt compensation, constant current demands, and active power transfers through the power angles embedded in the effective susceptances  $B_{ij}$ . The discrepancy between  $V_i/V_{\text{base}}$  and  $V_i/V_i^*$  can be quite extreme in heavily shunt-compensated networks, and it has been frequently noted in the literature that per unit voltages are poor indicators of proximity to voltage collapse. Our results to follow suggest that the ratios  $V_i/V_i^*$  of the voltage magnitudes to their open-circuit values are more appropriate indicators of voltage stability margins.

Finally, we note that that explicit upper and lower bounds  $V^{\text{lower}} \leq V_L \leq V^{\text{upper}}$  on the nodal voltage magnitudes may be present due to operational constraints. In general however, these upper and lower bounds may be asymmetric around the open circuit voltages, while the security set (29) is defined symmetrically. To conservatively formulate these bounds in terms of the stability set (29), one may assume that  $V^{\text{lower}} \leq V_L^* \leq V^{\text{upper}}$  and select  $\delta$  as

$$\delta_{\text{low}}^{\text{up}} = \min\left\{-\max_{i\in\mathcal{L}}\left(\frac{V_i^{\text{lower}}}{V_i^*} - 1\right), \min_{i\in\mathcal{L}}\left(\frac{V_i^{\text{upper}}}{V_i^*} - 1\right)\right\} \in [0,1].$$
(30)

With this choice, it holds that  $\overline{S}(\delta_{\text{low}}^{\text{up}}) \subseteq \{V_L \mid V^{\text{lower}} \leq V_L \leq V^{\text{upper}}\}$ , and thus any solutions which exist inside the set  $\overline{S}(\delta_{\text{low}}^{\text{up}})$  will also satisfy the explicit constraints.

The main result from the article is more formally stated as follows.

**Supplementary Theorem 1** (Voltage Stability Condition for Complex Power Networks). For the RPFE (8), define the stiffness matrix  $Q_{\text{crit}} \in \mathbb{R}^{n \times n}$  as in (25). Assume that the network parameters and loads satisfy

$$\Delta \triangleq \|Q_{\text{crit}}^{-1} Q_L\|_{\infty} < 1, \qquad (31)$$

and accordingly define the percentage deviations  $\delta_{-} \in [0, \frac{1}{2}[$  and  $\delta_{+} \in ]\frac{1}{2}, 1]$  as the unique solutions to  $\Delta = 4\delta_{\pm}(1 - \delta_{\pm})$ . The following statements hold:

- 1) Secure Solution: There exists a unique locally voltage-stable solution  $V_L \in \overline{S}(\delta_-)$  of the RPFE (8);
- 2) Solutionless Region: There exist no solutions of the RPFE (8) in the open set

$$\{V_L \in \mathbb{R}^n \mid V_L > (1 - \delta_+) V_L^* \text{ and } V_L \notin \overline{\mathcal{S}}(\delta_-)\}.$$
(32)

Moreover, the condition (31) is tight: there exists a critical load profile  $Q_L = Q_{\text{crit}}\mathbb{1}_n$  for which 1) there exists no locally voltage-stable solution  $V_L \in \overline{S}(\delta_-)$  for any  $\delta_- \in [0, \frac{1}{2}[$ , and 2) there exists a solution of the RPFE (8) in the open set (32) for any  $\delta_- \in [0, \frac{1}{2}[$  and any  $\delta_+ \in ]\frac{1}{2}, 1]$ . *Proof:* Statements 1 and 2): Assuming for the moment that no component of  $V_L$  is zero, we may rearrange the RPFE (8) to obtain

$$V_L = V_L^* - B_{LL}^{-1} [V_L]^{-1} Q_L \,. \tag{33}$$

Consider the bijective change of variable  $x \triangleq [V_L^*]^{-1}V_L - \mathbb{1}_n$ . The new variable x can be thought of as a percentage deviation of  $V_L$  from the open-circuit voltage  $V_L^*$ . Note that from the definition of the stability set in (29),  $V_L \in \overline{\mathcal{S}}(\delta)$  (resp.  $\mathcal{S}(\delta)$ ) if and only if  $x \in \overline{\mathcal{B}}_{\infty}(\delta)$  (resp.  $\mathcal{B}_{\infty}(\delta)$ ). Writing (33) in terms of the new percentage deviation variable x, we obtain the equivalent representation

$$x = f(x) \triangleq -[V_L^*]^{-1} B_{LL}^{-1} [V_L^*]^{-1} [Q_L] r(x)$$
(34a)

$$= -\frac{1}{4}Q_{\rm crit}^{-1}[Q_L]r(x), \qquad (34b)$$

where  $Q_{\text{crit}}$  is as in (25) and  $r(x) \triangleq (\frac{1}{1+x_1}, \dots, \frac{1}{1+x_n})$ . Having transformed the RPFE (8) into (34b), we now apply contraction mapping arguments to (34b). This procedure consists of two steps:

**Step 1:** First, we regard (34b) as the equilibrium equation of the discrete-time dynamical system

$$x(k+1) = f(x(k)), \qquad k \in \{1, 2, \ldots\},$$
(35)

and, under the parametric condition (31), show that there exists a  $\delta \in [0, 1]$  such that the  $\infty$ -norm ball  $\overline{\mathcal{B}}_{\infty}(\delta)$  is forward-invariant for the dynamics (35). In particular, we will show that there exists a  $\delta_{-} \in [0, \frac{1}{2}[$  and a  $\delta_{+} \in [\frac{1}{2}, 1]$  such that  $\overline{\mathcal{B}}_{\infty}(\delta)$  is forward-invariant for each  $\delta \in [\delta_{-}, \delta_{+}]$ , and that the iterates of (35) originating in  $] - \delta_{+}, \infty[^{n}$  eventually reach the forward-invariant set  $\overline{\mathcal{B}}_{\infty}(\delta_{-})$ .

**Step 2:** Second, we show that f is a contraction mapping on the forward-invariant set  $\overline{\mathcal{B}}_{\infty}(\delta_{-})$ , and apply the Banach Fixed Point Theorem [38, Chapter 9].

Step 1: Suppose  $x(k) \in \mathcal{B}_{\infty}(1)$  for some  $k \in \{1, 2, \ldots\}$ . Then there exists a  $\delta \in [0, 1[$  such that  $x(k) \in \overline{\mathcal{B}}_{\infty}(\delta)$ , with  $||x(k)||_{\infty} = \delta$ . We will first bound  $||x(k+1)||_{\infty}$ , and look for a condition under which  $||x(k+1)||_{\infty} \leq ||x(k)||_{\infty}$ . We compute using (35) and (34b) that

$$\|x(k+1)\|_{\infty} = \frac{1}{4} \|Q_{\text{crit}}^{-1}[Q_L]r(x(k))\|_{\infty}.$$
(36)

Using Assumptions 1 and 2 and Lemma 1, it holds that  $-Q_{\text{crit}}^{-1} = -4[V_L^*]^{-1}B_{LL}^{-1}[V_L^*]^{-1}$  has positive elements. Moreover,  $Q_L$  has nonpositive elements, and each component of r(x(k)) is strictly positive as  $||x(k)||_{\infty} = \delta < 1$ . We therefore compute

$$\frac{1}{4} \|Q_{\text{crit}}^{-1}[Q_L]r(x(k))\|_{\infty} \le \frac{\|Q_{\text{crit}}^{-1}[Q_L]\|_{\infty}}{4} \|r(x(k))\|_{\infty}$$
(37a)

$$= \frac{\|Q_{\text{crit}}^{-1}[Q_L]\|_{\infty}}{4} \|r(x(k))\|_{\infty}$$
(37b)

$$=\frac{\Delta}{4}\frac{1}{1-\delta}\,.\tag{37c}$$

Using this result and the fact that  $||x(k)||_{\infty} = \delta$ , it follows that  $||x(k+1)||_{\infty} \le ||x(k)||_{\infty}$  if  $\frac{\Delta}{4} \frac{1}{1-\delta} \le \delta$ , or equivalently

$$\Delta \le 4\delta(1-\delta) \,. \tag{38}$$

The right-hand side of (38) is a nonnegative and concave function of  $\delta \in [0, 1[$ , which achieves its global maximum of one at  $\delta^* = \frac{1}{2}$ . Thus, there exists a set of values for  $\delta \in [0, 1[$  with non-empty interior satisfying the inequality (38) if and only if (38) is true with strict inequality sign when  $\delta = \delta^* = \frac{1}{2}$ . This corresponds exactly to the parametric condition (31). If these equivalent conditions are true, there exist two unique values  $\delta_- \in [0, \frac{1}{2}[$  and  $\delta_+ \in [\frac{1}{2}, 1]$  satisfying (38) with equality sign, given by  $\delta_{\pm} = \frac{1}{2}(1 \pm \sqrt{1 - \Delta})$ . These arguments are shown graphically in Supplementary Fig. 3. The preceding calculations show that for each  $\delta \in [\delta_-, \delta_+]$ , the set  $\overline{\mathcal{B}}_{\infty}(\delta)$  is forward-invariant for the discrete-time dynamics (35), since  $x(k) \in \overline{\mathcal{B}}_{\infty}(\delta)$  leads to  $x(k+1) \in \overline{\mathcal{B}}_{\infty}(\delta)$ . Moreover, for each  $\delta \in [\delta_-, \delta_+]$  (resp.  $\delta \in ]\delta_-, \delta_+[$ ), we have that  $||x(k+1)||_{\infty} \leq ||x(k)||_{\infty}$  (resp.  $||x(k+1)||_{\infty} < ||x(k)||_{\infty}$ ) if  $||x(k)||_{\infty} = \delta$ . That is, the norm of iterates is non-increasing (resp. strictly decreasing). It follows that iterates of (35) originating in  $\mathcal{B}_{\infty}(\delta_+)$  eventually reach the forward-invariant set  $\overline{\mathcal{B}}_{\infty}(\delta_-)$ .

To complete this step, note that since every component  $r_i(x_i) = 1/(1+x_i)$  of r(x) is a monotone decreasing function of  $x_i$ , for  $x(k) \in [-\delta_+, +\infty[^n]$ , it follows that  $||r(x(k))||_{\infty} < 1/(1-\delta_+)$ , and hence, by the previous result, that  $||x(k+1)||_{\infty} < \frac{\Delta}{4} \frac{1}{1-\delta_+} = \delta_+$ ; that is, we have  $x(k+1) \in \mathcal{B}_{\infty}(\delta_+)$ . Since f is continuous on  $[-\delta_+, +\infty[^n]$ , it follows by combining the above results that all iterates of (35) originating in  $[-\delta_+, \infty[^n]$  reach  $\overline{\mathcal{B}}_{\infty}(\delta_-)$ . The discrete-time dynamics (35) therefore have no equilibria within the set  $[-\delta_+, \infty[^n \setminus \overline{\mathcal{B}}_{\infty}(\delta_-)]$ , and thus (34b) has no solutions within the same set. This completes the proof of statement 2).

**Step 2:** Let  $\delta \in [0, \delta_{-}]$ , and let  $x \in \overline{\mathcal{B}}_{\infty}(\delta)$ . Using (34b), we calculate the Jacobian of f to be

$$\frac{\partial f}{\partial x}(x) = \frac{1}{4} Q_{\text{crit}}^{-1}[Q_L][r(x)]^2 \tag{39}$$

and as before, bound it for  $x \in \overline{\mathcal{B}}_{\infty}(\delta)$  as

$$\left\|\frac{\partial f}{\partial x}(x)\right\|_{\infty} \le \frac{\Delta}{4} \left\|[r(x)]^2\right\|_{\infty} \le \frac{\Delta}{4} \frac{1}{(1-\delta)^2} \,. \tag{40}$$

The map f is a contraction mapping on  $\overline{\mathcal{B}}_{\infty}(\delta)$  if we have

$$\frac{\Delta}{4} \frac{1}{(1-\delta)^2} \le \alpha \tag{41}$$

for some  $\alpha \in [0, 1]$  called the contraction rate. Selecting  $\alpha \triangleq \delta/(1-\delta) < 1$ , the contraction condition (41) is quickly seen to be equivalent to (38). We therefore once again have a set of values for  $\delta$ such that f is a contraction map if and only if (31) holds, with  $\delta_{-}$  being the limiting case of strict equality, yielding the contraction rate  $\alpha = \delta_{-}/(1-\delta_{-}) < 1$ . Thus, f is a contraction mapping on the invariant set  $\overline{\mathcal{B}}_{\infty}(\delta_{-})$ . It now follows from the Banach Fixed-Point Theorem [38] that f has a unique fixed-point  $x^* \in \overline{\mathcal{B}}_{\infty}(\delta_{-})$ , and therefore that the power flow (8) has a unique solution  $V_L \in \overline{\mathcal{S}}(\delta_{-})$ .

To complete the proof of statement 1), it remains only to show that the unique solution  $V_L \in \overline{\mathcal{S}}(\delta_-)$ 

is locally voltage-stable. From Lemma 2 this occurs if and only if the Hessian  $H(V_L)$  in (17b) of the energy function (12) is positive definite. Inserting (33) into the second term of  $H(V_L)$ , we find that

$$H(V_L) = -B_{LL} + [V_L]^{-2}[Q_L].$$
(42)

Substituting  $V_L = [V_L^*](\mathbb{1}_n + x)$ , left and right-multiplying by  $[V_L^*]/2$  and simplifying using (25), we obtain

$$M_1 = \frac{1}{4} [V_L^*] H(V_L) [V_L^*] = -\frac{1}{4} [V_L^*] B_{LL} [V_L^*] + \frac{1}{4} [Q_L] [\mathbb{1}_n + x]^{-2}$$
(43a)

$$= -Q_{\rm crit} + \frac{1}{4} [Q_L] [\mathbb{1}_n + x]^{-2} \,. \tag{43b}$$

According to Sylvester's Inertia Theorem [43],  $M_1$  has the same number of positive eigenvalues as  $M_2 \triangleq -Q_{\text{crit}}^{-1}M_1$ , and thus  $M_1$  is positive definite if and only if

$$I_n - \frac{1}{4}Q_{\rm crit}^{-1}[Q_L][\mathbb{1}_n + x]^{-2}$$
(44)

is anti-Hurwitz. Since  $-Q_{\text{crit}}$  is an irreducible *M*-matrix, the inverse  $Q_{\text{crit}}^{-1}$  has strictly negative elements. As it also holds that  $Q_L \leq \mathbb{O}_n$ , we conclude that  $\frac{1}{4}Q_{\text{crit}}^{-1}[Q_L][\mathbb{1}_n + x]^{-2}$  is a nonnegative matrix. The Gershgorin Circle Theorem [37] then implies that all eigenvalues of  $\frac{1}{4}Q_{\text{crit}}^{-1}[Q_L][\mathbb{1}_n + x]^{-2}$ are contained within a disc centered at the origin of radius equal to the maximum row sum of the matrix, or equivalently, its  $\infty$ -norm. We compute that

$$\frac{1}{4} \|Q_{\text{crit}}^{-1}[Q_L][\mathbb{1}_n + x]^{-2}\|_{\infty} \le \frac{\Delta}{4} \frac{1}{(1 - \delta_-)^2} \le \alpha < 1.$$
(45)

It follows that all eigenvalues of  $\frac{1}{4}Q_{\text{crit}}^{-1}[Q_L][\mathbb{1}_n + x]^{-2}$  are less than one, which shows the desired result.

**Tightness:** To show the moreover statement we proceed by contraposition, and construct a load profile  $Q_L$  for which  $\Delta \geq 1$  and statements 1) and 2) fail. Consider the family of load profiles parameterized by  $\alpha \in [0, 1]$  defined by  $Q_L(\alpha) = \alpha \cdot Q_{\text{crit}} \mathbb{1}_n$ . Using (25) and (9) we compute that that

$$Q_{\rm crit} \mathbb{1}_n = \frac{1}{4} [V_L^*] B_{LL} [V_L^*] \mathbb{1}_n = \frac{1}{4} [V_L^*] B_{LL} V_L^*$$
(46a)

$$= -\frac{1}{4} [V_L^*] B_{LL} B_{LL}^{-1} (B_{LG} V_G + I_{\text{shunt}})$$
(46b)

$$= -\frac{1}{4} [V_L^*] (B_{LG} V_G + I_{\text{shunt}}) \,. \tag{46c}$$

From Assumption 4 and Lemma 1, we therefore have that  $Q_{\text{crit}}\mathbb{1}_n \leq \mathbb{O}_n$ . Hence, for every  $\alpha \in [0, 1]$ ,  $Q_L(\alpha) \leq \mathbb{O}_n$ , and (31) yields  $\Delta = \|Q_{\text{crit}}^{-1}Q_L(\alpha)\|_{\infty} = \|\alpha Q_{\text{crit}}^{-1}Q_{\text{crit}}\mathbb{1}_n\|_{\infty} = \alpha \|\mathbb{1}_n\|_{\infty} = \alpha$ .

Defining  $\delta_{\pm}(\alpha) \triangleq \frac{1}{2}(1 \pm \sqrt{1-\alpha})$ , one may verify by direct substitution that  $V_L^+(\alpha) = (1-\delta_-(\alpha))V_L^*$ and  $V_L^-(\alpha) = (1-\delta_+(\alpha))V_L^*$  are both particular solutions of (8). Moreover, for each  $\alpha \in [0, 1[$ , it holds that  $V_L^+(\alpha)$  is the unique locally voltage-stable solution, located exactly at the vertex of  $\overline{S}(\delta_-(\alpha))$  closest to the origin, while  $V_L^-$  can be verified to be voltage-unstable, similarly located at the vertex of  $\overline{\mathcal{S}}(\delta_+(\alpha))$  closest to the origin. It follows that for  $\alpha \in [0,1[, V_L^+(\alpha)$  is the unique solution in  $\overline{\mathcal{S}}(1/2)$ , and that for  $\alpha = 1$ ,  $V_L^+(\alpha) = V_L^-(\alpha) = V_L^*/2$  and the two solutions coalesce at a point of saddle-node bifurcation [25]. By continuity, we therefore have that no solutions can cross the boundary of  $\overline{\mathcal{S}}(1/2)$  from exterior to interior (that is, from  $\mathbb{R}^n \setminus \overline{\mathcal{S}}(1/2)$  to  $\mathcal{S}(1/2)$ ) as  $\alpha \to 1$ . Said differently, no previously existing solutions now belong to  $\mathcal{S}(1/2)$ . The only remaining option is that at  $\alpha = 1$ , a solution appears in  $\mathcal{S}(1/2)$  via a codimension one bifurcation [25]. However, the sudden appearance of such a solution precludes the existence of a continuously differentiable function  $G: \mathbb{R} \to \mathbb{R}^n$  defined on an open interval  $\mathcal{A}$  of  $\alpha = 1$  such  $G(\alpha)$  solves the RPFE (8) with load profile  $Q_L(\alpha)$  for each  $\alpha \in \mathcal{A}$ . It follows from the Implicit Function Theorem that the RPFE Jacobian (11) evaluated at this solution is singular [38]. Lemma 2 then precludes this new solution from being locally voltage-stable. Thus, there exists no value  $\delta \in [0, \frac{1}{2}]$  such that a unique, locally voltage-stable solution exists in  $\mathcal{S}(\delta)$ . This shows that statement 1) fails. To show that statement 2) fails as well, proceed by contradiction and assume that it holds. Then we expect there to exist values  $\delta_{-} \in [0, \frac{1}{2}]$  and  $\delta_{+} \in [\frac{1}{2}, 1]$  such that the RPFE (8) possesses no solutions in the open set of (32). However, inspection shows that for any such values  $\delta_{-}$  and  $\delta_{+}$ ,  $V_{L} = V_{L}^{*}/2$  belongs to this set. This is a contradiction, completing the proof of the converse. 

**Remark 3** (Interpretations of Supplementary Theorem 1). Supplementary Theorem 1 generalizes the one-dimensional result of Proposition 1 and Supplementary Fig. 2 to complex networks by taking into account the coupling between nodes of the network. Under the equivalent conditions of Supplementary Theorem 1, the positive orthant in the space of voltages is partitioned into three disjoint sets: the stability set  $\overline{S}(\delta_{-})$  where the locally voltage-stable solution exists, a region surrounding the stability set where all solutions are forbidden, and a low-voltage regime which may or may not contain additional power flow equilibria. For the case of two loads, this partitioning is shown in Supplementary Fig. 4(b), with the corresponding partitioning of parameter-space shown in Supplementary Fig. 4(a). The inverse  $Q_{\text{crit}}^{-1}$  can be interpreted as the sensitivity matrix relating variations in load to variations in nodal voltage deviation (see (50) in "Power Network Perspective" below). The eigenvector corresponding to the largest eigenvalue of  $-Q_{\text{crit}}^{-1}$  determines the most sensitive directions in load-space [44, 45, 46]. An interesting contrast to the seminal works [44, 45, 46] is that  $Q_{\text{crit}}^{-1}$  is symmetric, indicating that the same eigenvector describes both the most sensitive direction in load-space as well as the most sensitive direction in scaled  $(V_i/V_i^*)$  voltage-space.  $\Box$ 

**Remark 4** (Necessity of Stability Condition). While in general only a sufficient condition for the existence of a high-voltage solution, the condition (31) is tight for the critical loading profile  $Q_L = Q_{\text{crit}} \mathbb{1}_n$ , for which  $\Delta = 1$  and  $\delta_- = \delta_+ = 1/2$ , in agreement with the necessary and tight condition of Proposition 2, that is, for this direction in load space, the condition is both <u>necessary and sufficient</u>. To understand what this loading profile looks like, consider (46c) with  $I_{\text{shunt}} = \mathbb{0}_n$  for simplicity. Then the ith element of  $Q_{\text{crit}} \mathbb{1}_n$  is nonzero if and only if load bus  $i \in \mathcal{L}$  is attached directly to a generator. Thus, this critical load profile corresponds to loading only at the most well-supported buses in the network, the load buses adjacent to generators.

**Complex Networks Interpretation:** Defining  $V_{\min} \triangleq \min_{i \in \mathcal{L}} (V_L^*)_i$ , a sufficient condition for (31) is that

$$\|Q_L\|_{\infty} < \frac{1}{4} |\lambda_1(B_{LL})| V_{\min}^2 , \qquad (47)$$

where  $|\lambda_1(B_{LL})|$  is the smallest eigenvalue (in magnitude) of  $B_{LL}$ . This spectral condition, similar to the ones in [6, 7], uses only the first eigenvalue of the admittance matrix  $B_{LL}$  as a measure of network connectivity, while our more precise condition (31) implicitly uses all *n* network eigenvalues.

**Power Network Perspective:** In power system engineering, the nonlinear active power flow equations (3a) are often approximated by a heuristic called the "DC" power flow [26]. In the DC power flow, phase angles  $\theta_i - \theta_j$  are assumed to be sufficiently small such that  $\sin(\theta_i - \theta_j) \simeq \theta_i - \theta_j$ , and voltage magnitudes  $V_i$  are approximated as  $V_i = 1$  p.u. The active power balance (3a) then becomes a linear equation relating active power injections to phase angle differences. We now define a voltage/reactive power counterpart to this DC power flow approximation, and explain how its solution can be used to interpret the nonlinear voltage stability condition (31). Linearizing the right-hand side of (8) around the open-circuit solution  $V_L^*$ , we obtain [22, 7]

$$Q_L = -\operatorname{diag}(V_L^*)B_{LL}(V_{\operatorname{approx}} - V_L^*).$$
(48)

Performing the change of variables to the percentage deviation vector  $x_{\text{approx}}$  via

$$V_{\text{approx}} = \text{diag}(V_L^*)(\mathbb{1}_n + x_{\text{approx}})$$
(49)

and solving, we obtain the solution

$$x_{\text{approx}} = -\frac{1}{4} Q_{\text{crit}}^{-1} Q_L \,. \tag{50}$$

Hence, the voltage stability condition (31) reads simply as  $||x_{approx}||_{\infty} < 1/4$ , and can be interpreted as follows: the nonlinear power flow equations (8) have a unique, stable solution satisfying  $|V_i - V_i^*|/V_i^* < 1/2$  if the percentage deviation *calculated from the linear power flow* (48) is less than 25% at each bus.

**Resistive Circuit Interpretation:** The voltage stability condition (31) can be interpreted as a restriction on the solution of a linear resistive circuit, defined on a new graph. Consider the original graph  $G(\mathcal{V}, \mathcal{E})$  and construct a new graph  $G_L(\mathcal{L}, \mathcal{E}_L)$  by 1) removing all generator buses  $\mathcal{G}$ , and 2) removing each weighted edge  $\{i, j\} \in \mathcal{E}$  between generator i and load j, and replacing it with a shunt connection to ground of equal weight at node j; see Supplementary Fig. 1. For the nodal current injections  $I \triangleq \operatorname{diag}(V_L^*)^{-1}Q_L$ , and letting  $v = (v_1, \ldots, v_n)$  be the vector of nodal voltages, the linear current balance relations are [14]

$$I = -B_{LL}v \qquad \Longleftrightarrow \qquad v = RI, \tag{51}$$

where  $R \triangleq -B_{LL}^{-1}$  is the resistance matrix. Our voltage stability condition (31) then reads that  $\|\text{diag}(V_L^*)^{-1}RI\|_{\infty} = \|\text{diag}(V_L^*)^{-1}v\|_{\infty} \leq \delta(1-\delta)$ . That is, the normalized solution of this linear resistive circuit must have no node with voltage greater than  $\delta(1-\delta)$ . The elements  $R_{ij} \geq 0$  of the resistance matrix quantify the resistive distance between load nodes, accounting for all current-carrying paths through the original circuit. The "driving point impedances"  $R_{ii}$  satisfy  $R_{ii} \geq R_{ij}$  for all  $i, j \in \mathcal{L}$  [4], and for distinct nodes  $i, j \in \mathcal{L}, R_{ij} > 0$  if and only if there exists a path between i and j in the new graph  $G_L(\mathcal{L}, \mathcal{E}_L)$ . It follows from (51) that the voltage at node  $i \in \mathcal{L}$  is most sensitive to changes in its local load demand  $Q_i$ , and decreasingly sensitive to load nodes that are more electrically distant. This captures the classic power systems intuition that reactive power

flows are *localized* in a network.

Supplementary Theorem 1 implies a useful voltage-space proximity index, which the reader may have inferred from Supplementary Fig. 4.

Corollary 1 (Proximity to Low-Voltage Solution). Define the parametric Venikov index

$$K_{\rm V} \triangleq \sqrt{1 - \Delta} \,, \tag{52}$$

and let  $V_L^{\text{other}} \in \mathbb{R}^n$  be any solution of the RPFE (8) other than the secure solution of Supplementary Theorem 1 statement 1). Then

$$\frac{|V_i - V_i^{\text{other}}|}{V_i^*} \ge K_{\text{V}}, \quad i \in \mathcal{L}.$$
(53)

*Proof:* While from Supplementary Theorem 1 statement 1) the secure solution belongs to the set  $\overline{\mathcal{S}}(\delta_{-})$ , from Supplementary Theorem 1 statement 2) we have that all other solutions must lie outside the set  $](1-\delta_{+})V_{L}^{*}, \infty_{n}[$ , and therefore in particular outside the set  $\mathcal{S}(\delta_{+})$ . We may therefore write  $V_{L} = [V_{L}^{*}](\mathbb{1}_{n} + x)$  and  $V_{L}^{\text{other}} = [V_{L}^{*}](\mathbb{1}_{n} + x^{\text{other}})$  for  $x \in \overline{\mathcal{B}}_{\infty}(\delta_{-})$  and  $x^{\text{other}} \in \mathbb{R}^{n} \setminus \mathcal{S}(\delta_{+})$ . We compute that

$$\|[V_L^*]^{-1}(V_L - V_L^{\text{other}})\|_{\infty} = \|x - x^{\text{other}}\|_{\infty} \ge \delta_+ - \delta_-.$$
(54)

From Supplementary Theorem 1 it holds that  $\Delta = 4\delta_{\pm}(1 - \delta_{\pm})$ , and therefore that  $\delta_{\pm} = \frac{1}{2}(1 \pm \sqrt{1 - \Delta})$ . We therefore compute that

$$\delta_{+} - \delta_{-} = \frac{1}{2} \left( 1 + \sqrt{1 - \Delta} \right) - \frac{1}{2} \left( 1 - \sqrt{1 - \Delta} \right)$$
(55a)

$$=\sqrt{1-\Delta}=K_{\rm V}\,,\tag{55b}$$

which completes the proof.

By direct comparison, the index (52) is seen to be an appropriate multi-dimensional generalization of the parametric Venikov index (24). To the authors knowledge, this is the first such parametric result available in the literature. In terms of the energy function (12),  $\sqrt{1-\Delta}$  can be understood as a lower bound on the distance between the stable and unstable equilibria; c.f. Figure 1(c) of the main article.

**Remark 5** (The Effects of Power Angles and Decoupling). As can be seen by examining (2b), the voltage phase angles  $\theta_i - \theta_j$  enter the reactive power flow equations as a product  $B_{ij} \cos(\theta_i - \theta_j)$  with the off-diagonal elements of the admittance matrix B. It follows that any deviation of the phase angle differences from zero tends to weaken the effective coupling term  $B_{ij} \cos(\theta_i - \theta_j)$  between buses  $i, j \in \mathcal{L}$ . This is particularly clear for the two node system of (20). In this case, one may verify that  $v^* = V_G \cos(\theta)$ , that  $q_{crit} = \frac{1}{4}bV_G^2 \cos^2 \theta$ , and that  $\Delta = q_L/q_{crit}$ , where  $\theta$  is the angular difference between the two nodes. As  $|\theta|$  increases, the reactive power limit  $q_{crit}$  decreases, and tends to zero as  $|\theta| \to \pi/2$ . Moreover,  $1/q_{crit}$  is exactly the sensitivity of the loading margin  $\Delta$ with respect to changes in reactive power demands, and this sensitivity increases as active power flows increase. This is elegantly expressed by Van Cutsem in [47], where he writes "... the reactive power margin implicitly reflects the system stress imposed by the active power transfers, since the margin is a reserve after imposing the active load to be satisfied. As an example, if one would (fictitiously) approach collapse through only active load increases, the reactive margin would tend to zero as well."

In terms of the vector formulation (7), the above observations translate to a reduction in the offdiagonal elements of the sub-block  $B_{LL}$  as well as a reduction in the non-zero elements of  $B_{GL}$ . Accordingly, this active/reactive power coupling tends to weaken the stiffness matrix  $Q_{crit}$ , thereby increasing the network stress  $\Delta$ . To summarize, increasing active power flows appear in our formulation through the stiffness matrix  $Q_{crit}$ , and lead to increasing sensitivity of voltage deviations with respect to changes in reactive power demands. While not a full description of the nonlinear crosscoupling between active and reactive power flow, this behavior is consistent with the knowledge that increasing active power demands compromise voltage stability and push the system towards voltage collapse [47, 18, 48].

While active/reactive power coupling is mostly negligible in normal transmission system operation and under light loading conditions, it can become the dominant effect as voltage collapse is approached. There are two factors to consider here. Firstly, using any fixed set of phase angles in the effective susceptance matrix will underestimate the phase angles that occur as one moves closer to voltage collapse; the stiffness of the effective stiffness matrix  $Q_{\rm crit}$  will therefore be overestimated. The second factor is less important and more subtle: solvability of the coupled power flow equations is not equivalent to individual solvability of decoupled active and reactive power flow. We therefore expect the analytic stability condition derived for the simplified decoupled reactive power flow (8) to be optimistic near the point of collapse, unless power factors are low. Our voltage collapse simulation study in the main article (see Experiment 2 in Supplementary Methods for details) confirms this intuition.

# Supplementary Note 6 – Monotonicity of Stability Margins With Respect to Parameters: Results and Counterexamples

We now briefly explore how perturbations in the network parameters influence the value of the loading margin  $\Delta$  defined in (31). From the spring network analogy of Figure 1(b) in the main article and from general intuition, one would expect the following monotonicity results:

- (a) strengthening the connection between any generator and any load should decrease the value of  $\Delta$ ;
- (b) increasing generator voltage levels should decrease  $\Delta$ ;
- (c) increasing shunt compensation should decrease  $\Delta$ .

It turns out that statement (a) is false in general, while statements (b) and (c) are true.

**Example 1** (Counterexample to (a)). Consider two generators at voltages  $V_1$  and  $V_2$  connected to a single load at voltage  $V_0$  through susceptances  $-b_1$  and  $-b_2$ , with a shunt capacitor of susceptance  $b_s$  present at the load. Assumption 1 in this case becomes  $b_1 + b_2 - b_s > 0$ , and we assume for simplicity that no constant current load is present at the load. Then the reactive power balance equation (7) becomes

$$Q_L = V_0 \left( (b_1 + b_2 - b_s) V_0 - b_1 V_1 - b_2 V_2 \right) \,. \tag{56}$$

One may verify explicitly that  $Q_{\text{crit}}$  in this case is given by

$$|Q_{\rm crit}| = \frac{(V_1b_1 + V_2b_2)^2}{4(b_1 + b_2 - b_{\rm s})}.$$
(57)

Since there is only a single load, monotonicity of  $\Delta = Q_L/Q_{crit}$  with respect to changes in  $b_1$  or  $b_2$  is equivalent to monotonicity of  $Q_{crit}$ . In particular, conventional engineering wisdom suggests that  $|Q_{crit}|$  should be an increasing function of either parameter, that is, strengthening the network should reduce the risk of collapse. An easy calculation gives that

$$\frac{\mathrm{d}}{\mathrm{d}b_2}|Q_{\mathrm{crit}}| = \frac{V_2}{4} \frac{(V_1b_1 + V_2b_2)}{b_1 + b_2 - b_\mathrm{s}} \left(b_2 - 2b_\mathrm{s} + 2b_1\left(1 - \frac{1}{2}\frac{V_1}{V_2}\right)\right). \tag{58}$$

When  $b_2 > 2b_{bs} - 2b_1(1 - V_1/2V_2)$ ,  $|Q_{crit}|$  is a monotone increasing function of  $b_2$  as expected. When this inequality is violated however we find that strengthening the second transmission line decreases stability margins. In the case  $b_s = 0$ , this turning point will exist if and only if  $V_1 > 2V_2$ , while if  $V_1 = V_2 = V$ , this turning point exists if and only if  $b_s > b_1/2$ . While these parametric conditions are extreme and would not occur in real-world networks, this example highlights the theoretical issue with claim (a), and nonetheless suggests that one should be cautious when upgrading transmission infrastructure.

In this example we observe that either strong heterogeneity of generator voltages, the presence of large shunts, or both can cause a lack of monotonicity. We will show that when these factors are absent, the original intuition is correct. Consider a nominal network, and let  $b_{LG} \in \mathbb{R}_{\geq 0}^{n \times m}$  be a nonnegative matrix where the ijth element is the desired increase in coupling between generator  $i \in \mathcal{G}$  and load  $j \in \mathcal{L}$ . To avoid the trivial case where the original and modified networks are identical, we assume that at least one element of  $b_{LG}$  is strictly positive. The modified network is represented by the new network matrices  $\overline{B}_{LG} = B_{LG} + b_{LG}$ , and  $\overline{B}_{LL} = B_{LL} - \text{diag}(b_{LG}\mathbb{1}_m)$ , along with the new open-circuit voltages  $\overline{V}_L^* = -\overline{B}_{LL}^{-1}\overline{B}_{LG}V_G$ . For simplicity, we ignore constant current loads in the following proposition.

**Proposition 3** (Effects of Load-Generator Coupling Increases). Consider the nominal network and the modified network as described above, with stiffness matrices  $Q_{\text{crit}} = \frac{1}{4}[V_L^*]B_{LL}[V_L^*]$  and  $\overline{Q}_{\text{crit}} = \frac{1}{4}[\overline{V}_L^*]\overline{B}_{LL}[\overline{V}_L^*]$  respectively. Assume that there are no shunt susceptances present, and that all generator voltages are equal to the same constant  $V_g > 0$ . Then it holds element-wise that  $\overline{Q}_{\text{crit}}^{-1} > Q_{\text{crit}}^{-1}$ .

Since  $Q_{\text{crit}}^{-1}$  and  $\overline{Q}_{\text{crit}}^{-1}$  are strictly negative matrices (Assumptions 1–2), the inequality  $\overline{Q}_{\text{crit}}^{-1} > Q_{\text{crit}}^{-1}$ indicates that the elements of  $\overline{Q}_{\text{crit}}^{-1}$  are smaller in magnitude than those of  $Q_{\text{crit}}^{-1}$ . It follows immediately that  $\overline{\Delta} < \Delta$ ; the network stress has decreased. Comparing Proposition 3 to the results of Example 1, we note that the assumptions of no shunt susceptances and uniform generator voltages are only sufficient for monotonicity, and not necessary. Nonetheless, the parametric setting in Proposition 3 is much closer to reality than the exotic parameters required in Example 1.

*Proof.* Under the assuption of no shunt susceptances, the matrices  $-B_{LL}^{-1}B_{LG}$  and  $-\overline{B}_{LL}^{-1}\overline{B}_{LG}$  are both row-stochastic [49, Lemma II.1]. Since  $V_G = V_g \mathbb{1}_m$ , it follows that  $V_L^* = \overline{V_L^*} = V_g \mathbb{1}_n$ , and

hence that  $Q_{\text{crit}} = V_g^2 B_{LL}/4$  and  $\overline{Q}_{\text{crit}} = V_g^2 \overline{B}_{LL}/4$ . By Assumptions 1–2, it holds that  $-B_{LL}$  is an irreducible *M*-matrix, and since  $b_{LG}$  is nonnegative, it follows that  $-\overline{B}_{LL} = -B_{LL} + \text{diag}(b_{LG}\mathbb{1}_m)$  is also an irreducible *M*-matrix. We conclude that  $-\overline{B}_{LL} + B_{LL}$  is positive definite. It follows immediately by properties of irreducible *M*-matrices [50] that  $-\overline{B}_{LL}^{-1} < -B_{LL}^{-1}$  element-wise, and the result follows.

To study changes in generator voltages, we again consider a nominal network and a modified network, where now the modified network is constructed by changing the generator voltage setpoints to  $\overline{V}_G = V_G + v_G$ , where  $v_G \ge 0_n$  with at least one strictly positive element. The open-circuit voltages in the modified network are given by  $\overline{V}_L^* = -B_{LL}^{-1}B_{LG}\overline{V}_G$ . In this case, we observe, as expected, that raising the generator voltages improves the distance to voltage collapse.

**Proposition 4** (Effects of Generator Voltage Increases). Consider the nominal network and the modified network as described above, with stiffness matrices  $Q_{\text{crit}} = \frac{1}{4}[V_L^*]B_{LL}[V_L^*]$  and  $\overline{Q}_{\text{crit}} = \frac{1}{4}[\overline{V_L^*}]B_{LL}[\overline{V_L^*}]$ . Then it holds element-wise that  $\overline{Q}_{\text{crit}}^{-1} > Q_{\text{crit}}^{-1}$ .

Proof. Note that  $\overline{V_L^*} = -B_{LL}^{-1}B_{LG}\overline{V}_G = -B_{LL}^{-1}B_{LG}(V_G + v_G) = V_L^* + v_L^*$ , where  $v_L^* = -B_{LL}^{-1}B_{LG}v_G$ . From Assumptions 1–2, it follows that  $-B_{LL}^{-1}B_{LG}$  is a positive matrix, consequently  $v_L^* > \mathbb{O}_n$  component-wise, and hence that  $\overline{V_L^*} > V_L^*$  component-wise as well. Note then that for any  $i, j \in \mathcal{L}$ ,

$$-(\overline{Q}_{\rm crit}^{-1})_{ij} = \frac{-4(B_{LL}^{-1})_{ij}}{\overline{V_i^*} \cdot \overline{V_j^*}} < \frac{-4(B_{LL}^{-1})_{ij}}{V_i^* \cdot V_j^*} = -(Q_{\rm crit}^{-1})_{ij},$$
(59)

which shows the desired result.

Finally, to study changes in shunt compensation we again consider a nominal network and a modified network. We let  $B_s = \text{diag}(b_{s,1}, \ldots, b_{s,n}) \geq \mathbb{O}_n$  denote the diagonal matrix of additional shunt capacitors affixed at the load nodes, and we assume that at least one element of  $B_s$  is strictly positive. The grounded susceptance matrix for the modified network is given by  $\overline{B}_{LL} = B_{LL} + B_s$ , which we assume is also a (negative) *M*-matrix. The modified open-circuit voltages are  $\overline{V}_L^* = -\overline{B}_{LL}^{-1}B_{LG}V_G$ . We omit the proof of the following result, which can be shown similarly to the previous two. The following result confirms the conventional practice that shunt compensation improves the stability of the network. We omit the proof, which follows analogous arguments as the proofs of Proposition 3 and 4.

**Proposition 5** (Effects of Shunt Capacitor Increases). Consider the nominal network and the modified network as described above, with stiffness matrices  $Q_{\text{crit}} = \frac{1}{4}[V_L^*]B_{LL}[V_L^*]$  and  $\overline{Q}_{\text{crit}} = \frac{1}{4}[\overline{V_L^*}]\overline{B}_{LL}[\overline{V_L^*}]$ . Then it holds element-wise that  $\overline{Q}_{\text{crit}}^{-1} > Q_{\text{crit}}^{-1}$ .

In summary, we find that the stability margin  $\Delta$  defined in (31) can be leveraged to provide insight into how the parameters of the original network influence voltage stability, and that the stability margin may display a lack of monotonicity with respect to parameters.

## Supplementary Note 7 – Voltage Stability Condition Incorporating Generator Injection Limits

As discussed in the generator modeling of Supplementary Note 2, synchronous generators are typically subject to capability curve limits [18], which in the context of this paper correspond to upper and lower limits on the reactive power  $Q_i$  which can be injected at a generator  $i \in \mathcal{G}$ . While the results of Supplementary Theorem 1 (or equivalently, Theorem 1 of the main article) give sufficient conditions for the existence of a unique voltage-stable solution of (6), no *a priori* constraints were placed on the resulting generator reactive power injections, which are determined *a posteriori* by evaluating the right-hand side of (2b) at the system operating point. There may be situations where the physical network is able to support the transfer of reactive power (that is, (6) possess a voltage-stable solution), but the resulting generator limits are violated, meaning that the operating point is infeasible in practice. Our goal now is to generalize the voltage stability condition of Supplementary Theorem 1 to ensure the existence of a voltage-stable solution subject to generator reactive power injections satisfying predetermined limits.

The generator reactive power injections  $Q_G \in \mathbb{R}^m$ , given by (2b) at nodes  $i \in \mathcal{G}$ , are written in vector notation as

$$Q_G = -[V_G](B_{GG}V_G + B_{GL}V_L), (60)$$

where  $B_{GG}$  and  $B_{GL}$  are the appropriate blocks of the effective susceptance matrix (refer back to the block partitioned matrix (1)). Here we will focus on generator injection upper bounds  $Q_G^{\text{upper}} \in \mathbb{R}^m$  (so-called overexcitation) since this is the most relevant case for voltage collapse; analogous arguments can be made for underexcitation limits. We introduce two quantities related to generator injections that will help us to succinctly state our results. We define the open-circuit generator injections  $Q_G^* \in \mathbb{R}^m$  and the auxiliary injections  $Q_{\text{aux}} \in \mathbb{R}_{>0}^m$  by

$$Q_G^* \triangleq -[V_G](B_{GG}V_G + B_{GL}V_L^*), \qquad (61)$$

$$Q_{\text{aux}} \triangleq [V_G] B_{GL} V_L^* \,. \tag{62}$$

The open-circuit injections  $Q_G^*$  are the generator injections one would observe when the constant power loads  $Q_L$  are set to zero, while the vector of auxiliary injections  $Q_{\text{aux}}$  will serve as useful scaling factors. We make the plausible and necessary assumption that  $Q_G^* < Q_G^{\text{upper}}$ component-wise; the open-circuit injections satisfy the generator limits. For convenience, let  $\bar{\mathcal{G}} = \{i \in \mathcal{G} \mid \text{there exists } j \in \mathcal{L} \text{ s.t. } B_{ij} \neq 0\}$  be the set of generators which are connected to at least one load. It is straightforward to see that if  $i \in \bar{\mathcal{G}}$  then the corresponding component of  $Q_{\text{aux}}$  as defined in (62) is non-zero.

The next result generalizes Supplementary Theorem 1 (and hence, Theorem 1 of the main article) to account for generator limits.

Supplementary Theorem 2 (Voltage Stability Condition Including Generator Limits). Consider the RPFE (8) and the generator injections (60). Let  $Q_G^{upper} \in \mathbb{R}^m$  be desired upper bounds in the generator injections,  $Q_G < Q_G^{upper}$ , and let the open-circuit injections  $Q_G^*$  and the auxiliary injections  $Q_{aux}$  be as defined as in (61)–(62). Consider the (normalized) minimum generator injection slack

$$\delta_{\text{constr}} \triangleq \min_{i \in \bar{\mathcal{G}}} \frac{Q_{G,i}^{\text{upper}} - Q_{G,i}^*}{Q_{\text{aux},i}} > 0, \qquad (63)$$

and let  $\overline{\Delta} > 0$  be defined by

$$\overline{\Delta} \triangleq \begin{cases} 4\delta_{\text{constr}}(1-\delta_{\text{constr}}), & \text{if } \delta_{\text{constr}} < 1/2, \\ 1, & \text{if } \delta_{\text{constr}} \ge 1/2. \end{cases}$$
(64)

Assume that

$$\Delta \triangleq \|Q_{\text{crit}}^{-1}Q_L\|_{\infty} < \overline{\Delta}\,,\tag{65}$$

and accordingly define the percentage deviation  $\delta_{\text{unconstr}}$  as the unique solution to  $\Delta = 4\delta(1-\delta)$ belonging to the interval  $[0, \frac{1}{2}[$ . Finally, set  $\delta_{-} = \min(\delta_{\text{constr}}, \delta_{\text{unconstr}}) \in [0, \frac{1}{2}[$ . Then the RPFE (8) has a unique voltage-stable solution  $V_L \in \overline{\mathcal{S}}(\delta_{-})$  and the generator injections (60) satisfy the constraints  $Q_G < Q_G^{\text{upper}}$ .

Before proving Supplementary Theorem 2 we make several comments. First, note that  $\overline{\Delta}$  depends only on  $\delta_{\text{constr}}$ , which in turn depends only on fixed parameters of our problem setup, such as the network topology/weights, generator voltage setpoints, and generator injection limits. Thus, like the stability condition (31) in Supplementary Theorem 1, the stability condition (65) is purely parametric.

Second, to see that the unconstrained case of Supplementary Theorem 1 is embedded in Supplementary Theorem 2, consider what happens when the generator injections limits  $Q_G^{\text{upper}}$  are large. Then the generator injection slack  $\delta_{\text{constr}}$  in (63) is large,  $\overline{\Delta}$  in (64) evaluates to 1, and the stability condition (65) reduces to the previous condition of Supplementary Theorem 1. In this regime, the network is limited only by insolvability of the reactive power flow equations, and not by generator limits; the same argument holds whenever  $\delta_{\text{constr}} > \delta_{\text{unconstr}}$ . Conversely, when  $\delta_{\text{constr}} < \delta_{\text{unconstr}}$ , network stability is limited by generator limits, and  $\overline{\Delta} - \Delta$  becomes the loading margin which implicitly quantifies the remaining slack in parameter-space for which generation limits are guaranteed to be met. The conservativeness of this stability margin will vary from network to network depending on the precise values of the generator limits  $Q_G^{\text{upper}}$ .

Proof: We first prove the statements regarding the unique solution of (8). First consider the case where  $\delta_{\text{constr}} \geq 1/2$ . It then holds that  $\overline{\Delta} = 1$ , the condition (65) reduces to the unconstrained stability condition (31) of Supplementary Theorem 1,  $\delta_{-} = \delta_{\text{unconstr}} = (1 - \sqrt{1 - \Delta})/2$ , and all the conclusions follow. In the case where  $\delta_{\text{constr}} < 1/2$ , the inequality (65) takes the form  $\Delta \leq 4\delta_{\text{constr}}(1 - \delta_{\text{constr}})$ . Comparing this to (38) from the proof of Supplementary Theorem 1, it follows that there exists a unique voltage-stable solution  $V_L \in \overline{S}(\delta_{\text{constr}})$  to the RPFE (8). Moreover, since  $\Delta < \overline{\Delta} < 1$ ,  $\delta_{\text{unconstr}}$  also remains well defined, so there exists a unique voltage-stable solution  $V_L \in \overline{S}(\delta_{\text{unconstr}})$  as well. It follows that there exists a unique voltage-stable solution  $V_L \in \overline{S}(\delta_{\text{constr}}) \cap \overline{S}(\delta_{\text{unconstr}}) = \overline{S}(\delta_{-})$  as claimed.

It remains only to show that the generator constraints are satisfied. Under the assumed conditions we can write the load voltages as  $V_L = [V_L^*](\mathbb{1}_n + x)$  where x belongs to the vector interval  $x \in [-\delta_-\mathbb{1}_n, \delta_-\mathbb{1}_n]$ . Using this and (61), substitution shows that the generator injections (60) can be written as

$$Q_G = -[V_G](B_{GG}V_G + B_{GL}V_L) = Q_G^* - [V_G]B_{GL}[V_L^*]x = Q_G^* - Q_{aux}x.$$
 (66)

Since  $[V_G]B_{GL}[V_L^*]$  is a nonnegative matrix and  $V_L \in \overline{\mathcal{S}}(\delta_-)$  (meaning that all  $x_i \in [-\delta_-, \delta_-]$ ), we

may upper bound the right-hand side of (66) by inserting  $-\delta_{-}\mathbb{1}_n$  for x, resulting in the element-wise vector inequality

$$Q_G \le Q_G^* + \delta_- \cdot Q_{\text{aux}} \le Q_G^* + \delta_{\text{constr}} \cdot Q_{\text{aux}} \,, \tag{67}$$

where the second inequality follows since  $\delta_{\text{constr}} \geq \delta_{-}$  by definition. There are now two cases to consider. If  $Q_{\text{aux},i} = 0$ , then the corresponding constraint is satisfied since  $Q_{G,i}^* < Q_{G,i}^{\text{upper}}$  by assumption. If  $Q_{\text{aux},i} \neq 0$ , then the corresponding constraint  $Q_{G,i}^* < Q_{G,i}^{\text{upper}}$  is satisfied if and only if  $\delta_{\text{constr}} \leq (Q_{G,i}^{\text{upper}} - Q_{G,i}^*)/Q_{\text{aux},i}$  at each generator  $i \in \mathcal{G}$ , which holds by the definition of  $\delta_{\text{constr}}$ . Thus the generator constraints are satisfied, completing the proof.

## Supplementary Methods

Here we provide additional details regarding the numerical experiments presented in the main article.

#### Experiment 1 – Voltage Stability Assessment for Test Networks

To establish the accuracy of the voltage stability condition (31) over a large set of power networks, we consider a smart grid scenario in which both generation and demand are subject to fluctuations due to a high penetration of renewable generation and controllable demand response. To generate a large sample of randomized test cases, we modify the nominal simulation parameters [51, 52] as follows. For each of the eleven test cases under consideration, we construct 1000 realizations by

- (i) Fluctuating load: Through a uniform distribution over all buses, we first select 30% of buses in the network for load randomization. The base case active/reactive power injections (P<sub>i</sub>, Q<sub>i</sub>) at each selected bus are randomized as (1 + α<sub>i</sub>)P<sub>i</sub> and (1 + α<sub>i</sub>)Q<sub>i</sub>, where α<sub>i</sub> is pulled from a Gaussian distribution with mean zero and standard deviation 0.5.
- (ii) **Fluctuating generation:** Through a uniform distribution over all generator buses, we first select 30% of the generators in the network for randomization. The base case active power generation  $P_i$  at each selected generator is randomized as  $(1 + \alpha_i)P_i$ , where  $\alpha_i$  is pulled from a Gaussian distribution with mean zero and standard deviation 0.3.
- (iii) **Redispatch:** Since the above randomization procedure can lead to a large imbalance between total scheduled generation and total demand, we calculate the imbalance (neglecting losses) and distribute the imbalance uniformly across the unrandomized generators.

For each realization, we numerically calculate using MATPOWER [51] the exact solution  $(\theta, V_L) \in \mathbb{T}^{n+m} \times \mathbb{R}^n_{>0}$  to the lossless coupled power flow equations (3a) (if the Newton-Raphson solver diverges while attempting to find the solution, we discard the trial and repeat it). We then compute the maximum voltage deviation of the exact solution as

$$\delta_{\text{exact}} \triangleq \max_{i \in \mathcal{L}} \frac{|V_i - V_i^*|}{V_i^*} \,. \tag{68}$$

To apply our theory, we use the calculated phase angles  $\theta$  to build the effective susceptance matrix (Supplementary Note 2, Power Angle Decoupling), we compute the open-circuit voltages (9), the stiffness matrix (25), compute  $\Delta$  from (31) and finally compute our estimate  $\delta_{-} = \frac{1}{2}(1 - \sqrt{1 - \Delta})$  of the worst case normalized voltage deviation. The first column of Table 1 in the main article indicates that for all realizations constructed, it held that  $\Delta < 1$  and that  $\delta_{\text{exact}} \leq \delta_{-}$  as expected from Supplementary Theorem 1. The second, third, and fourth columns of Table 1 list the average values obtained for  $\delta_{\text{exact}}$ ,  $\delta_{-}$  and  $(\delta_{-} - \delta_{\text{exact}})/\delta_{\text{exact}}$  over all realizations for each network.

#### Experiment 2 – $\Delta$ as an Indicator of Voltage Collapse

In this experiment the continuation power flow implemented in MATPOWER was used to drive the New England 39 bus system towards voltage collapse, and test whether and how well the metric  $\Delta$  performs as a predictor of collapse. The direction in parameter space along which the system is incrementally loaded is specified in terms of a baseline set of loads and a target set of loads. The system is then loaded along the ray connecting the baseline configuration and the target configuration, tracing out the top-half of the nose curves shown in Figures 3 and 4 of the main article.

For our first study, the baseline profile was chosen as the default loading profile  $(P, Q_L)$ . The average power factor for load buses in this baseline profile is 0.88. The target profile was constructed by modifying the baseline profile as  $(P, 3.1 \times Q_L)$ , where the numerical value of 3.1 was selected such that the average power factor of load buses in the target profile equaled 0.7. This corresponds to a heavily reactive target profile, and hence as the system is loaded from the base profile through the target profile, the power factors of loads decrease, as is often the case under stressed network conditions.

For our second study, the baseline profile was again chosen as the default loading profile, and the target profile was also chosen as the default loading profile. Thus, as the system was loaded towards voltage collapse, all power injections were simply scaled up proportionally, with loads maintaining their original power factors of 0.88 on average.

For both studies,  $V_L^*$  and  $\Delta$  were computed as described in Experiment 1 for the lossless coupled power flow model (3a)–(3b). Bus four was selected for plotting purposes since it represented the most stressed bus in the network, displaying both the lowest per unit voltage along with having the highest component value from the vector  $Q_{\text{crit}}^{-1}Q_L$ . This was therefore the bus at which our theoretical bound  $V_i \geq V_i^*(1 - \delta_-)$  was most likely to be violated. As can be seen in Figures 3 and 4, the bound is quite tight near the base case and becomes looser as the system is progressively loaded.

#### Experiment 3 – Corrective Action

In this case study, we illustrate the utility of our condition (31) for online network stability monitoring and corrective action. First, we highlight how capacitive shunt compensation acts as a double-edged sword: capacitor banks assist in supporting the voltage magnitudes at load buses of the network, but simultaneously makes the true network stress unobservable through the network voltage profile. We show that our condition (31) can be used to accurately assess this hidden danger by providing a quantitative estimate of network stress. Second, we show how the voltage stability condition (31) suggests corrective action schemes to increase the stability margin of the network.

The stressed network case was created as follows, beginning from the base case data for the NE 39 bus system from MATPOWER. First, the network contained two capacitive loads, which we flipped in sign to create a heavier inductive loading profile. Next, all power demands in the network were scaled up uniformly by 70%, with their original power factors maintained. To avoid unrealistically overloading the slack bus, the resulting imbalance was dispatched uniformly over all generators. Loading at buses seven through nine was increased an additional 50%, again maintaining the original power factors. The power factor of bus eight was then lowered to 0.82 by adding additional reactive load. Shunt compensation was placed uniformly across the network to bring most of the voltages back within operational limits, with additional shunt compensation being placed locally at buses seven through nine to compensate for the additional loading present. The power flow was then solved for the full coupled power flow model including branch conductances.

Control action was implemented by curtailing the reactive power demands at buses seven and nine in the manner described in the main article. Accompanying this curtailment was an *equal* reduction in shunt compensation across buses seven through nine. That is, the total MVAR which would have been injected by the removed capacitors (at 1 p.u.) equaled the total reactive power curtailment applied at buses seven and nine. This can also be seen from Figure 5; the per-unit voltage profiles before and after are nearly identical, but stability margins (plotted as  $V_i/V_i^*$ ) are substantially improved by substituting stiff reactive power injections for shunt compensation, and properly selecting the locations for reactive power injection.

# Supplementary References

- Meyer, C. & Stadelmaier, M. Singular M-matrices and inverse positivity. *Linear Algebra and its Applications* 22, 139–156 (1978).
- [2] Berman, A. & Plemmons, R. J. Nonnegative Matrices in the Mathematical Sciences (SIAM, 1994).
- [3] Wu, F. F. & Kumagai, S. Limits on Power Injections for Power Flow Equations to Have Secure Solutions (Electronics Research Laboratory, College of Engineering, University of California, 1980).
- [4] Wu, F. & Kumagai, S. Steady-state security regions of power systems. *IEEE Transactions on Circuits and Systems* 29, 703–711 (1982).
- [5] Kaye, R. & Wu, F. Analysis of linearized decoupled power flow approximations for steady-state security assessment. *IEEE Transactions on Circuits and Systems* **31**, 623–636 (1984).
- [6] Thorp, J., Schulz, D. & Ilić-Spong, M. Reactive power-voltage problem: conditions for the existence of solution and localized disturbance propagation. *International Journal of Electrical Power & Energy Systems* 8, 66–74 (1986).

- [7] Bolognani, S. & Zampieri, S. On the existence and linear approximation of the power flow solution in power distribution networks. *IEEE Transactions on Power Systems* **31**, 163–172 (2015).
- [8] Chiang, H. & Baran, M. On the existence and uniqueness of load flow solution for radial distribution power networks. *IEEE Transactions on Circuits and Systems* 37, 410–416 (1990).
- [9] Lesieutre, B. C., Sauer, P. W. & Pai, M. A. Existence of solutions for the network/load equations in power systems. *IEEE Transactions on Circuits and Systems I: Fundamental Theory and Applications* 46, 1003–1011 (1999).
- [10] Dib, W., Barabanov, A. E., Ortega, R. & Lamnabhi-Lagarrigue, F. An explicit solution of the power balance equations of structure preserving power system models. *IEEE Transactions on Power Systems* 24, 759–765 (2009).
- [11] Sanchez, S., Ortega, R., Bergna, G., Molinas, M. & Grino, R. Conditions for existence of equilibrium points of systems with constant power loads. In *IEEE Conf. on Decision and Control*, 3641–3646 (Florence, Italy, 2013).
- [12] Grijalva, S. & Sauer, P. W. A necessary condition for power flow Jacobian singularity based on branch complex flows. *IEEE Transactions on Circuits and Systems I: Fundamental Theory* and Applications 52, 1406–1413 (2005).
- [13] Grijalva, S. Individual branch and path necessary conditions for saddle-node bifurcation voltage collapse. *IEEE Transactions on Power Systems* 27, 12–19 (2012).
- [14] Kundur, P. Power System Stability and Control (McGraw-Hill, 1994).
- [15] Skar, S. J. Stability of multi-machine power systems with nontrivial transfer conductances. SIAM Journal on Applied Mathematics 39, 475–491 (1980).
- [16] Baillieul, J. & Byrnes, C. I. Remarks on the number of solutions to the load flow equations for a power system with electrical losses. In *IEEE Conf. on Decision and Control*, vol. 21, 919–924 (Orlando, FL, USA, 1982).
- [17] Horn, R. A. & Johnson, C. R. Matrix Analysis (Cambridge University Press, 1985).
- [18] Machowski, J., Bialek, J. W. & Bumby, J. R. Power System Dynamics (John Wiley & Sons, 2008), 2 edn.
- [19] Hiskens, I. A. & Chakrabarti, B. B. Direct calculation of reactive power limit points. International Journal of Electrical Power & Energy Systems 18, 121 – 129 (1996).
- [20] Hiskens, I. A. Analysis tools for power systems contending with nonlinearities. Proceedings of the IEEE 83, 1573–1587 (2002).
- [21] Simpson-Porco, J. W., Dörfler, F. & Bullo, F. Voltage stabilization in microgrids via quadratic droop control. In *IEEE Conf. on Decision and Control*, 7582–7589 (Florence, Italy, 2013).

- [22] Gentile, B., Simpson-Porco, J. W., Dörfler, F., Zampieri, S. & Bullo, F. On reactive power flow and voltage stability in microgrids. In *American Control Conference*, 759–764 (Portland, OR, USA, 2014).
- [23] Taylor, C. W. Power System Voltage Stability (McGraw-Hill, 1994).
- [24] Pal, M. K. Voltage stability: analysis needs, modelling requirement, and modelling adequacy. Generation, Transmission and Distribution, IEE Proceedings C 140, 279–286 (1993).
- [25] Dobson, I. The irrelevance of load dynamics for the loading margin to voltage collapse and its sensitivities. In Bulk Power System Voltage Phenomena - III (Davos, Switzerland, 1994).
- [26] Dörfler, F. & Bullo, F. Novel insights into lossless AC and DC power flow. In *IEEE Power & Energy Society General Meeting* (Vancouver, BC, Canada, 2013).
- [27] Dörfler, F., Chertkov, M. & Bullo, F. Synchronization in complex oscillator networks and smart grids. Proceedings of the National Academy of Sciences 110, 2005–2010 (2013).
- [28] Pal, M. K. Voltage stability conditions considering load characteristics. *IEEE Transactions on Power Systems* 7, 243–249 (1992).
- [29] Milanovic, J. V., Yamashita, K., Villanueva, S. M., Djokic, S. Z. & Korunovic, L. M. International industry practice on power system load modeling. *IEEE Transactions on Power* Systems 28, 3038–3046 (2013).
- [30] Ilić, M. Network theoretic conditions for existence and uniqueness of steady state solutions to electric power circuits. In *IEEE International Symposium on Circuits and Systems*, 2821–2828 (San Diego, CA, USA, 1992).
- [31] Sauer, P. W. & Pai, M. A. Power system steady-state stability and the load-flow Jacobian. IEEE Transactions on Power Systems 5, 1374–1383 (1990).
- [32] Overbye, T. J. Effects of load modelling on analysis of power system voltage stability. International Journal of Electrical Power & Energy Systems 16, 329–338 (1994).
- [33] Van Cutsem, T. & Vournas, C. Voltage Stability of Electric Power Systems (Springer, 1998).
- [34] Venikov, V. A., Stroev, V. A., Idelchick, V. I. & Tarasov, V. I. Estimation of electrical power system steady-state stability in load flow calculations. *IEEE Transactions on Power Apparatus* and Systems 94, 1034–1041 (1975).
- [35] Löf, P.-A., Hill, D. J., Arnborg, S. & Andersson, G. On the analysis of long-term voltage stability. International Journal of Electrical Power & Energy Systems 15, 229–237 (1993).
- [36] Van Cutsem, T. Voltage instability: phenomena, countermeasures, and analysis methods. Proceedings of the IEEE 88, 208–227 (2000).
- [37] Meyer, C. D. Matrix Analysis and Applied Linear Algebra (SIAM, 2001).
- [38] Rudin, W. Principles of Mathematical Analysis. International Series in Pure and Applied Mathematics (McGraw-Hill, 1976), 3 edn.

- [39] Overbye, T. J., Dobson, I. & DeMarco, C. L. Q-V curve interpretations of energy measures for voltage security. *IEEE Transactions on Power Systems* 9, 331–340 (1994).
- [40] Chiang, H.-D. & Jean-Jumeau, R. Toward a practical performance index for predicting voltage collapse in electric power systems. *IEEE Transactions on Power Systems* 10, 584–592 (1995).
- [41] Abe, S. & Isono, A. Determination of power system voltage stability. Part 1: Theory. Electrical Engineering in Japan 96, 171–178 (1976).
- [42] Reis, C. & Barbosa, F. P. M. A comparison of voltage stability indices. In *IEEE Mediterranean Electrotechnical Conference*, 1007–1010 (Malaga, Spain, 2006).
- [43] Carlson, D. & Schneider, H. Inertia theorems for matrices: The semidefinite case. Journal of Mathematical Analysis and Applications 6, 430–446 (1963).
- [44] Dobson, I. & Lu, L. Computing an optimum direction in control space to avoid stable node bifurcation and voltage collapse in electric power systems. *IEEE Transactions on Automatic Control* 37, 1616–1620 (1992).
- [45] Cañizares, C. A. Calculating optimal system parameters to maximize the distance to saddlenode bifurcations. *IEEE Transactions on Circuits and Systems I: Fundamental Theory and Applications* 45, 225–237 (1998).
- [46] Capitanescu, F. & Van Cutsem, T. Unified sensitivity analysis of unstable or low voltages caused by load increases or contingencies. *IEEE Transactions on Power Systems* 20, 321–329 (2005).
- [47] Cutsem, T. V. A method to compute reactive power margins with respect to voltage collapse. IEEE Transactions on Power Systems 6, 145–156 (1991).
- [48] Hiskens, I. A. & Davy, R. J. Exploring the power flow solution space boundary. IEEE Transactions on Power Systems 16, 389–395 (2001).
- [49] Dörfler, F. & Bullo, F. Kron reduction of graphs with applications to electrical networks. IEEE Transactions on Circuits and Systems I: Regular Papers 60, 150–163 (2013).
- [50] Horn, R. A. & Johnson, C. R. Topics in Matrix Analysis (Cambridge University Press, 1994).
- [51] Zimmerman, R. D., Murillo-Sánchez, C. E. & Thomas, R. J. MATPOWER: Steady-state operations, planning, and analysis tools for power systems research and education. *IEEE Transactions on Power Systems* 26, 12–19 (2011).
- [52] Grigg, C. et al. The IEEE Reliability Test System 1996. A report prepared by the Reliability Test System Task Force of the Application of Probability Methods Subcommittee. *IEEE Transactions on Power Systems* 14, 1010–1020 (1999).